

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 825-77 Issued 9/9/77 date
 Job Location 1058 N. Sheffield Ave. address
 Lot n/a sub div or legal discript
 Issued By Ronald D. Sonnenberg building official
 Owner Keith Buehrer 592-4332 tel.
 Address 1058 N. Sheffield Ave.
 Agent Self Same tel.
 Address Same
 Description of Use Brick & Aluminum on front of house.
 Residential XXX(10) no. dwelling units
 Commercial _____ Industrial _____
 New _____ Add'n. _____ Alter _____ Remodel XX
 Mixed Occupancy _____
 Change of Occupancy _____
 Estimated Cost \$400.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$3.00	---	\$3.00
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$3.00
LESS MIN. FEES PAID _____ date			-0-
BALANCE DUE.....			\$3.00

ZONING INFORMATION
n/a

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length 25' Width _____ Stories 1 Ground Floor Area _____
 Height 8' Building Volume (for demo. permit) _____ cu. ft.
 Electrical: _____ brief description _____
 Plumbing: _____ brief description _____
 Mechanical: _____ brief description _____
 Sign: _____ Dimensions _____ Sign Area _____
 Additional Information: SEE ATTACHED ADDENDUM:

Date Sept 12, 77 Applicant Signature Keith Buehrer
 owner-agent

CITY OF CHICAGO
BUILDING DEPARTMENT
APPLICATION FOR PERMIT TO CONSTRUCT

825-77
#3.00

The undersigned hereby makes application for the construction, installation, replacement or alteration of the following structure, equipment or work to be done on the premises of the applicant's property for the purpose of the following:

Owner's Name Keith Bucher Address 1058 N. Sheffield 7th Fl.
Builder's Name self Telephone 592-4332

LOT INFORMATION

Location of Project _____ Lot # _____
Subdivider _____ Lot Area _____ Sq. Ft. _____
Yard Set Back: Front _____ Side _____
Rear _____ Right of Way _____

BUILDING INFORMATION

Single Double _____
Addition _____ Remodel _____
Detached Garage _____ Accessory Building _____

Brief Description of Work: Brick half way up, aluminum siding
rest of way

Size: Length 9' Width 25' No. of Stories 7

Floor Area: 1st Floor _____ Sq. Ft. 2nd Floor _____ Sq. Ft.
Unfinished Area _____ Garage _____

Foundation: Piers _____ Full Basement _____ Half Basement _____
Concrete _____ Masonry Block _____ Size _____

Walls: Frame _____ Brick _____


Specific Type of Structure

APPLICATION FOR PERMIT SHALL BE SUBMITTED BY THE APPLICANT WITH SETS OF PLANS INCLUDING ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND LOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: \$ 400.00

DATE 9-1-77 APPLICANT'S SIGNATURE Keith Bucher

FRONT VIEW



RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON, Building Dept.
 255 West Riverview Avenue
 Napoleon, Ohio 43545
 (419) 592-4010

ADDENDUM to Permit No. 825-77

Owner K. BUEHRER
 Location 1050 N. SHEFFIELD

Please note the items checked below and incorporate them into your plans as indicated: Permit Issued Incorporate the items during construction. Permit not yet issued Correct Plans and Re-Submit.

GENERAL	
<p>Provide 1 approved smoke detector.</p> <p>Provide 1 hour fire wall and/or ceiling between garage and dwelling.</p> <p>Provide (Class B) 1 hour fire rated door from garage to dwelling.</p> <p>Submit fully dimensioned plot plan.</p> <p>Provide 1-3'0" x 6'8" exit door.</p> <p>Provide min. 22" x 30" attic access.</p> <p>Provide min. 18" x 24" crawl space access opening.</p> <p style="text-align: center;">LIGHT AND VENTILATION:</p> <p>Provide mechanical exhaust or window in bathroom.....</p> <p>Provide Min. _____ sq. in. net free area attic ventilation.</p> <p>Provide min. _____ sq. in. net free area crawl space ventilation.</p> <p style="text-align: center;">FOUNDATION:</p> <p>Min. depth of foundation below finished grade 30".</p> <p>Min. size of footer....." x"</p> <p>Provide anchor bolts 1/2" @ 8' o.c. 1' from each corner. Embedded 8" concrete and 15" in masonry.</p> <p>Show size of basement columns.</p> <p style="text-align: center;">FRAMING:</p> <p>Show size of wood girder in.....</p> <p>Provide design data for structural member in.....</p> <p>Floor joists under sized in.....</p> <p>Provide double joists under parallel partitions.</p> <p>Provide 1" x 4" let in corner bracing or approved sheathing.</p> <p>Show size of headers for openings over 4' wide.</p>	<p>Show size of members supporting porch roof.</p> <p>Provide double top plate.</p> <p>Provide design data for pre-fab. wood truss/members.</p> <p>Ceiling joists undersized in.....</p> <p>Roof rafters undersized in.....</p> <p style="text-align: center;">PLUMBING AND MECHANICAL:</p> <p>Terminate all exhaust systems to outside air.</p> <p>Insulate ducts in unheated areas.</p> <p>Provide back flow device on all hose bibs.</p> <p style="text-align: center;">ELECTRICAL:</p> <p>Show location of service entrance and service equipment panel.</p> <p>G.F.C.I. req'd. on Temp. Electric.</p> <p>Outdoor and bathroom receptacles shall be protected by G.F.C.I.</p> <p style="text-align: center;">METAL VENEERS:</p> <p><input checked="" type="checkbox"/> Contact City Utilities Dept. to remove conductors and/or meter. IF NECESSARY</p> <p>Provide 18" x 18" x 3/4" wood backer for meter base.</p> <p><input checked="" type="checkbox"/> Provide approved system of grounding and bonding.</p> <p style="text-align: center;">MISCELLANEOUS:</p> <p>Provide backwater valve in sub-soil drain tile.</p> <p><input checked="" type="checkbox"/> Provide approved sheathing and flashing behind masonry veneer.</p> <p>Provide 15# felt underlayment on roof.</p> <p>Provide adequate fireplace hearth extensions</p> <p>Install factory built fireplaces/stoves according to manufacturers recommendations.</p> <p>Terminate chimney 3' above roof or 2' above highest point of building within 10' of chimney.</p>

ADDITIONAL CORRECTIONS: ATTACH MASONRY VENEER TO SUPPORTING WALL WITH METAL TIES. VENEER SHALL BE SUPPORTED ON FOOTER OR FOUNDATION IN AN APPROVED MANNER.

The approval of plans and specifications does not permit the violation of any section of the Building Code, or other City Ordinance or State Law. This addendum is attached to Permit No. 825-77 and made a part thereof.

Date Approved or Disapproved 9-9-77
 Date Rechecked and Approved _____

Checked By Ron Sonnenberg
 Checked By _____
 Plan Examiner

