

1133 NORTH SHEFFIELD AVENUE

2015

INVESTIGATION OF ILLEGAL SEWER CONNECTIONS.
DYE TESTING CON FIRMED POUNSPOUT AND
DRIVEWAY DRAIN OUTLET TO STORM SEWER.
ALL DRAINS ARE IN COMPLIANCE AT THIS TIME.

