

# PERMIT

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
**255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010**

Permit No. 161-78 Issued 9/22/78  
date

Job Location 419 Sheffield Ave.  
address

Lot 5 Stelters Add'n.  
sub-div or legal discript

Issued By R.E. Johnson  
building official

Owner Donald Homan 592-2350  
name tel.

Address 737 Welsted Ave.

Agent Self  
builder-eng.-etc. tel.

Address \_\_\_\_\_

Description of Use Room Add'n.

Residential one  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. XX Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$2,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$9.00	0	\$9.00
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING	0	0	0
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$9.00
LESS MIN. FEES PAID _____			0
BALANCE DUE.....			\$9.00

### ZONING INFORMATION

district "A"	lot dimensions 90' x 69.56'	area 6,260sq'	front yd As per Exist.	side yds Min. 6' South OK	rear yd 17' OK
max hgt 25' OK	no pkg spaces n/a	no ldg spaces n/a	max cover 35% OK -	petition or appeal req'd -----	date appr ---

### WORK INFORMATION:

Size: Length 15' Width 8'6" Stories 1 Ground Floor Area 127.5sq'

Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: \_\_\_\_\_ brief description

Plumbing: \_\_\_\_\_ brief description

Mechanical: \_\_\_\_\_ brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

PAID

SEP 27 1978

CITY OF NAPOLEON

Additional Information: SEE ATTACHED ADDENDUM & CALL FOR INSPECTIONS MARKED ON ATTACHED SHEET:

Date Sept 27/78 Applicant Signature Donald F. Homan  
owner-agent

# INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
<b>PLUMBING</b>	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
<b>MECHANICAL</b>	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/ Plenums			Ducts/ Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
<b>ELECTRICAL</b>	Conduits & or Cable			Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
<b>BUILDING</b>	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
<b>ADDITIONAL</b>	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					
	CITY OF MADISON											
	PAID											
	SEP 27 1978											

OFFICE OF THE CITY ENGINEER  
CITY OF BOSTON  
DEPARTMENT OF PUBLIC WORKS  
BOSTON, MASSACHUSETTS

\$9.00

The undersigned hereby makes application for the construction, installation, maintenance and repair of the following described work to be done on the premises hereinafter described, and agrees to do all such work in accordance with the City of Boston's Building Code and all other laws and regulations of the City of Boston.

Name of Applicant DONALD HOMAN Address 419 SHEFFIED AVE.  
City SAME Telephone 737 WELSTED No. 599-2350

Location of Work 419 SHEFFIED Lot No. 5  
Subdiv. STELTER'S Area 6300 Sq. Ft.  
Front Elevation 30'-0" Side Elevation 17'-6" Rear Elevation 32'-0"  
Depth 8'-0" Remarks A

Use of Building RESIDENTIAL  
Scheme  REAR  FRONT  NEW CONSTRUCTION  
Attachment DETACHED  
Detached Garage  Basement   
Brief Description of Work REAR PORCH

Size: Length 15'-0" Width 8'-6" No. of Stories 1  
Floor Area: 1st Floor          Sq. Ft.  
2nd Floor          Sq. Ft.  
Basement          Sq. Ft.  
Foundation: Full          Part Basement           
Color:                                
Wall: Frame               Other         

Special Treatment of Walls wood

APPLICATION FOR PERMITS MUST BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, EXTERIOR FINISHES, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONAL OR REMARKS ARE NECESSARY, THE APPLICANT MUST INDICATE STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE MARKED TO SCALE.

Estimated Cost of Construction \$2,000  
Signature Donald F. Homan





# RESIDENTIAL PLAN CORRECTION SHEET

**CITY OF NAPOLEON, Building Dept.**  
**255 West Riverview Avenue**  
**Napoleon, Ohio 43545**  
**(419) 592-4010**

**ADDENDUM to Permit No.** 161-78  
**Owner** D. ADAMAN  
**Location** 419 SHEFFIELD AVE.

Please note the Items checked below and incorporate them into your plans as indicated:  Permit not yet issued  
**Correct Plans and Re-Submit.**     **Permit issued Incorporate the Items during construction.**

GENERAL	
Provide 1 approved smoke detector.	Show size of members supporting porch roof.
Provide 1 hour fire wall and/or ceiling between garage and dwelling.	Provide double top plate.
Provide (Class B) 1 hour fire rated door from garage to dwelling.	Provide design data for pre-fab. wood truss/members.
Submit fully dimensioned plot plan.	Ceiling joists undersized in .....
Provide 1-3'0" x 6'8" exit door.	Roof rafters undersized in .....
Provide min. 22" x 30" attic access.	<b>PLUMBING AND MECHANICAL:</b>
Provide min. 18" x 24" crawl space access opening.	Terminate all exhaust systems to outside air.
<b>LIGHT AND VENTILATION:</b>	Insulate ducts in unheated areas.
Provide mechanical exhaust or window in bathroom.....	Provide back flow device on all hose bibs.
Provide Min. _____ sq. in. net free area attic ventilation.	<b>ELECTRICAL:</b>
Provide min. _____ sq. in. net free area crawl space ventilation.	Show location of service entrance and service equipment panel.
<b>FOUNDATION:</b>	G.F.C.I. req'd. on Temp. Electric.
Min. depth of foundation below finished grade 30".	Outdoor and bathroom receptacles shall be protected by G.F.C.I.
Min. size of footer....." x ....."	<b>METAL VENEERS:</b>
<input checked="" type="checkbox"/> Provide anchor bolts 1/2" @ 8' o.c. 1' from each corner. Embedded 8" concrete and 15" in masonry.	Contact City Utilities Dept. to remove conductors and/or meter.
Show size of basement columns.	Provide 18" x 18" x 3/4" wood backer for meter base.
<b>FRAMING:</b>	Provide approved system of grounding and bonding.
Show size of wood girder in.....	<b>MISCELLANEOUS:</b>
Provide design data for structural member in.....	Provide backwater valve in sub-soil drain tile.
Floor joists under sized in.....	Provide approved sheathing and flashing behind masonry veneer.
Provide double joists under parallel partitions.	Provide 15# felt underlayment on roof.
Provide 1" x 4" let in corner bracing or approved sheathing.	Provide adequate fireplace hearth extensions
Show size of headers for openings over 4' wide.	Install factory built fireplaces/stoves according to manufacturers recommendations.
	Terminate chimney 3' above roof or 2' above highest point of building within 10' of chimney.

**ADDITIONAL CORRECTIONS:** PROVIDE HANDRAILS ON AT LEAST ONE SIDE OF BOTH STAIRWAYS & GUARD RAILS ON OPENSIDES OF STAIRWAYS

The approval of plans and specifications does not permit the violation of any section of the Building Code, or other City Ordinance or State Law. This addendum is attached to Permit No. 161-78 and made a part there-of.

**Date Approved or Disapproved** 9-22-78  
**Date Rechecked and Approved** \_\_\_\_\_

**Checked By** [Signature]  
 Plan Examiner  
**Checked By** \_\_\_\_\_

