

22294 Honeysuckle
Curtice, Ohio 43412

City Of Napoleon
FIELD SURVEY FORM

12 apt. each bldg.

Premises Address: ⁷⁸⁰ ~~22294~~ Sheffield Company Name: Candlelite Apts.
Contact Name: Tom Cavese Contact Phone No: 1-419-836-9065
Service No: 4336 Service Size: 1 1/2" Meter No: 40012738 Meter Size: 1 1/2" Date Installed: 7-12-95
Type of Inspection: Initial Follow-Up Date of Inspection: 3-25-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 4" System Pressure 65-75 psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

1-Hot Water Tank
1-Washing machine
12-bathrooms
12-Garbage disposals

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

Will need to install a expansion tank

BACKFLOW PREVENTION REQUIREMENTS

need to install a Reduced Pressure Assembly in The
Horizontal Position. immediately after The water meter

Water Dist. - White Customer - Canary Building Dept. - Pink