

City Of Napoleon
FIELD SURVEY FORM

Premises Address: 840 Sheffield Company Name: Pandelite Apt.
Contact Name: Tom Cruise Contact Phone No: 419-836-9065
Service No: 3936 Service Size: 1 1/2" Meter No: 1001272 Meter Size: 1 1/2" Date Installed: 7-28-95
Type of Inspection: Initial Follow-Up Date of Inspection: 3-25-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 4" System Pressure 65-75 psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

- 1- Hot Water Heater
- 1- Washing Machine
- 12- Bathrooms
- 12- Garbage disposals

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Spinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

Will need to install expansion tank

BACKFLOW PREVENTION REQUIREMENTS

need to install a Reduced Pressure Assembly in the Horizontal Position,
immediately after water meter