

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Norman Minnick
Address
Builder Name
Address Tel.

Lot Information:

Street No. 623 Strong
Lot Subdivision
Lot Dimensions Lot Area Sq. Ft.
Yard Set Back: Front Rear
Side Side

Sidewalk required in accordance with Ordinance
No.

Building Information:

Residence Commercial Industrial
Single Double Multiple New Construction Addition Remodel
Size: Length Width No. of Stories
Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
Unfinished Attic Garage
Foundation: Piers Full Basement Part Basement
Concrete Block
Walls: Frame Block Brick Other
Electrical Outlets: 120v 240v
Plumbing: Fixtures Traps Vents Heating Air Conditioning
Additional Information:

Date Applicant Signature

Inspection Record: Final Plumbing Tested & Approved by P.W.P. on 2/20/75
Final Electrical Inspected & approved by N. Howes 2/21/75

Work Started Foundations Plumbing, Heating
Set Back, Side Lines Plumbing (Rough In) OK 5-1-74 And Air Conditioning
Excavation Erecting Frame 10-2-73 Roof Shed 10-8-73
Footing Electrical Work OK by Meyers 5-2-74

Comments: EXCEPT BETTER WIRE SUPPORTING

Certificate of Occupancy Issued ON 2-28-75, No 019 By Sharon W. Linnora
Inspector

Permit No.	<u>92-73</u>			
Issued			
By Building Inspector			
Estimated Cost			
	Fees	Base	Plus	Total
Construction
Basement
Detached Garage
Plumbing
Electrical
Heating
Air Conditioning
Water Tap
Sewer Tap
Temporary Electric
Total

CITY OF NAPOLEON
 Engineering Department
 255 Riverview Avenue
 NAPOLEON, OHIO 43545

DATE 2-20-75	JOB NO. 92-73
PROJECT Dwelling Remodel.	
LOCATION 623 Strong St.	
CONTRACTOR Self, Owner	OWNER -
WEATHER	TEMP. ° at AM ° at PM
PRESENT AT SITE	

TO NORMAN MINNICK
623 Strong St.
NAPOLEON, OHIO

THE FOLLOWING WAS NOTED:

- ① GROUNDING OF SERVICE EQUIP. TO CITY WATER LINE. ART. 250, NEC.
- ② NM CABLE WHERE RUN EXPOSED MUST BE PROTECTED FROM PHYSICAL DAMAGE. ART. 300 NEC.
- ③ NM CABLES WHERE RUN WITHIN 3" OF HEAT GREATER THAN THE DESIGN OF CABLE (60°C) MUST HAVE PROTECTION. ART. 300 NEC.
- ④ ALL DEVICE OUTLETS WHERE WITHIN 5' HORIZ. OF A PLUMBING OUTLET OR A GROUNDED HEATING, THE DEVICE MUST BE GROUNDED. ART. 350 NEC.
- ⑤ RECEPT OUTLET FOR COUNTER TOPS - 1 1/2" x 1 1/2" x 1 1/2" APPROVED. ART. 220 - NEC.
- ⑥ - SUPPORTS FOR SERVICE MAST - WITHIN 36" OF EACH TERMINATION ART 300, NEC.

Completed & inspected by P.W.P. on 2/26/75

- Install Ventilating Fans in both Bath Rms.
- Provide additional support in basement for main wood girder. P.W.P. 2/20/75

COPIES TO Norman and on record with

Blk Permit No. 92-73

FIELD REPORT

SIGNED Norman Minnick

Elect. Insp.