

599-9276

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 779-777 Issued 7/14/77 date

Job Location 702 Strong St. address

Lot n/a subdiv or legal discript

Issued By Ronald D. Soumebley building official

Owner Mrs. Louis Brown name tel.

Address 702 Stong St.

Agent XXXXXelling's Plumbing & Heating builder-eng.-etc. tel.

Address Rt. 2 Napoleon 598-8991

Description of Use New electric service & Air conditioner

Residential XXX(1) no. dwelling units

Commercial Industrial

New Add'n. Alter Remodel XXX

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$1250.00

ZONING INFORMATION
n/a

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

✓ w/ COCHRAN
WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: New 100 amp service entrance & air conditioner. brief description

Plumbing: _____ brief description

Mechanical: _____ brief description

Sign: _____ type _____ Dimensions _____ Sign Area _____

Additional Information: Shall conform to 1975 edition of N. E. C. Also see attached addendum.


Date July 15-77 Applicant Signature Earl H. Elling owner-agent

	FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING				
<input checked="" type="checkbox"/> ELECTRICAL	\$3.00		----	\$3.00
<input type="checkbox"/> PLUMBING				
<input type="checkbox"/> MECHANICAL				
<input type="checkbox"/> DEMOLITION				
<input type="checkbox"/> ZONING				
<input type="checkbox"/> SIGN				
WATER TAP				
SEWER TAP				
TEMP. ELECT.				
ADDITIONAL PLAN REVIEW		Struct.	_____ hrs	
		Elect.	_____ hrs	
TOTAL FEES.....				\$3.00
LESS MIN. FEES PAID _____ date _____				-0-
BALANCE DUE.....				\$3.00

INSPECTION RECORD

UNDERGROUND			ROUGH-IN			FINAL		
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains		Drainage, Waste & Vent Piping			Drainage, Waste & Vent Piping		
	Water Piping		Water Piping			Backflow Prevention		
	Building Sewer		Water Piping			Water Heater		
	Sewer Connection					FINAL APPROVAL		
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s)		
	Ducts/Plenums		Duct Furnace(s)			Fire Dampers		
			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)		
			Duct Insulation			Pool Heater		
ELECTRICAL	Conduits & or Cable		Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer		
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors		
	Floor Ducts Raceways		Service Panel Switchboard		5-11 78 NH	<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder		
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable		
BUILDING	Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)		
	Location, Set-backs, Esmt(s)		Exterior Wall Construction			Roof Covering Roof Drainage		
	Excavation					Exterior Lath		
	Footings & Reinforcing					<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard		
ADDITIONAL	Floor Slab		Interior Wall Construction			Fire Wall(s)		
	Foundation Walls		Columns & Supports			Fireplace Chimney		
	Sub-soil Drain		Crawl Space			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access		
	Piles		Floor System(s)			Roof System		
			INSPECTIONS, CORRECTIONS, ETC.			INSPECTIONS, CORRECTIONS, ETC.		

6-1
78 NH
 Electric Mtr. Clearance
 FINAL APPROVAL
 Smoke Detector
 Demolition (sewer cap)



REVISIONS		
NO.	DATE	BY
1		
2		
3		

Mrs Louis T. Brown Job

Elling's Plb & Htg

DRAWN BY SCALE MATERIAL



REVISIONS			DESIGNED BY	CHECKED BY	DATE
NO.	DATE	BY			
1					
2					

779-77

#3.00

Mrs. Louis F. Brown 702 Strong 598-8991
 Ellingsø Pk. & Hwy R#2

X

X /

750

100

~~YES~~ NO

/

/

NO

July 11-77

\$12.50⁰⁰

Earl H. Elling

CITY OF NAPOLEON

BUILDING & ZONING INSPECTION DEPARTMENT

FIELD CORRECTION NOTICE

LOCATION 702 Avonc St PERMIT NO. 779-77

ISSUED TO Mrs. Louis Brown
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO COCHRAN ELECTRIC

Upon inspection, violations of the NATIONAL ELECTRIC CODE Sec. JFE BELOW were in evidence.

The following orders are hereby issued for their correction:

- ① - GROUNDING 6-1-78 Complied 50-81 NEC
- ② - INDEX PNL BOARD " 110-22 NEC
6-1-78 N.A.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE at once BY M. Howes INSPECTOR
DATE 5-11-78

FIELD COPY.

Date: 7-14-77

TO: Electric Distribution Superintendent

FROM: The Building Inspector - Building Department

Please confirm the installation of 100 AMP. electrical service entrance, located SAME AS EXIST. ?

at the following address: 702 SIKONG ST.

Approved:

Not Approved

K. Lange
Electric Supt.

7-19-77
Date

Remarks:

