

CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
 (1, 2 or 3 Family Dwelling)

Owner Name Lynn Hensch
 Address 718 Strong St.
 Builder Name Sherman Smith Electrical Co.
 Address Rt. #2, Napoleon Tel. 592-7791

Lot Information:

Street No. 718 Strong St.
 Lot 221 Subdivision Sheffield's 3rd Add
 Lot Dimensions Lot Area Sq. Ft.
 Yard Set Back: Front Rear
 Side Side

Zoning "B" Intended use of Building: Installing to the rear of the existing dwelling in the same location a new 200AMP service entrance with the main distribution panel located in the basement.

Building Information:

Single Double Multiple New Construction Addition Remodel
 Size: Length Width No. of Stories
 Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
 Unfinished Attic Garage
 Foundation: Piers Full Basement Part Basement
 Concrete Block
 Walls: Frame Block Brick Other
 Electrical: Wiring 200AMP Electric Heating -- Electrical Appliances --
 Plumbing: Fixtures or Traps -- Warm Air Heating -- Hot Water Heating --

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 7-25-75 Applicant Signature Sherman Smith Elect.
 Owner - Builder - Agent

Permit No.	<u>235-75</u>		
Issued	<u>7/23/75</u>		
By	<u>Franklin ...</u> Building Inspector		
Valuation	<u>2350.00/75</u>		
	Fees	Base	Plus
Construction		
Plumbing		
Electrical	<u>\$3.00</u>	<u>\$14.35</u>	<u>\$17.35</u>
Heating		
Water Tap		
Sewer Tap		
Temporary Elec.		
TOTAL	<u>\$3.00</u>	<u>\$14.35</u>	<u>\$17.35</u>

Inspection Record:

Work Started Foundations Plumbing, Heating
 Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
 Excavation Erecting Frame Roof
 Footing Electrical Work 7/24/75 Disapproved by Howes
 Comments: 7/28/75 All condition corrected & re inspected
by P.W.P.
 Certificate of Occupancy Issued

Pink - Engineer

Inspector

1st 10 circuits @ 1.75
Bult 60 each 15.60

3 26
60
15.60
1.75

Dave ok'd same
Location of dwelling, far rear
7/23/75

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

Total 17.35

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name LYNN RAUSCH Address 718 STRONG ST.

Contractor's Name SHERMAN SMITH Address RT2 Tel. 592 7991

LOT INFORMATION: 221

Location of Project Shelby's 3rd Zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing Addition _____

Replacement Remodel _____ Service Change

Size: Total Square Foot Per Floor _____ No. of Stories 1 1/2

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only YES (Yes or No)

Smith informed me → Total Number of New Circuits 40 Excluding Appliance Circuits
Existing 6 circuits

* APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric _____ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: 200.00

DATE 7-16-75 APPLICANT'S SIGNATURE Sherman Smith
OWNER-CONTRACTOR-AGENT

Not RECD
CAUTION

✓ Requires Load Data
+ RISER DIAG.

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 7-20-75

Permit No. 335-75

Type of Inspection Rough Elect.

Type of Occupancy Dwelling

Project Name L. Lausch

Address 718 Strong

City Napoleon State OHIO

Approved

Violation

Electrical Contractor Smith

Remarks:

Code Reference

① GROUNDING CONDUCTOR FROM DRIVEN ROD MUST TERMINATE ON NEUTRAL BAR IN METER ENCLOSURE WITH A CU-AL SPACER CITY ORD

② GROUNDING CONDUCTOR FROM CITY WATER LINE MUST TERMINATE ON NEUTRAL BAR IN SERVICE EQUIPMENT

③ SERVICE DROP CONDUCTORS AND SERVICE ENTRANCE CONDUCTORS MUST CLEAR WINDOWS, PLATFORMS ETC BY 3 FT

④ City of Napoleon Adopted 1975 National Code July 1-1975

7/28/75 Corrected & Inspected by P.W.J.

250-81 NEC

330-2J C NEC

Compliance Time 7 days

Inspectors Signature Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector