

**PERMIT**

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
**255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010**

Permit No. 80-79 Issued 7-2-79  
date

Job Location 825 Strong St.  
address

Lot n/a  
sub-div or legal discript

Issued By [Signature]  
building official

Owner Mrs. Bud Rowe  
name tel.

Address 825 Strong St. Nap, Ohio

Agent Jim Speiser & Sons 599-1846  
builder-eng.-etc. tel.

Address RR 2 Napoleon, Ohio

Description of Use New service entrance

Residential one  
no. dwelling units

Commercial Industrial

New      Add'n.      Alter      Remodel XX

Mixed Occupancy     

Change of Occupancy     

Estimated Cost \$ 400.00

FEE	BASE	PLUS	TOTAL
BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$5.00		\$5.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. <u>    </u> hrs		
	Elect. <u>    </u> hrs		
TOTAL FEES.....			\$5.00
LESS MIN. FEES PAID <u>    </u> date <u>    </u>			0
BALANCE DUE.....			

**ZONING INFORMATION**

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

**WORK INFORMATION:**

Size: Length      Width      Stories      Ground Floor Area     

Height      Building Volume (for demo. permit)      cu. ft.

Electrical: Install new 100 amp service - no new circuits.  
brief description

Plumbing:       
brief description

Mechanical:       
brief description

Sign:      Dimensions      Sign Area       
type

Additional Information: CALL FOR INSPECTION.

**PAID**  
**JUL 13 1979**  
**CITY OF NAPOLEON**

Date 7-13-79 Applicant Signature [Signature]  
owner-agent



3.50

CITY OF BOSTON  
ELECTRIC INSPECTION DEPARTMENT  
APPLY FOR PERMIT FOR ELECTRICAL WORK  
General Form No. 1

Application for installation or replacement of electrical equipment, including wiring, including in all work on electrical equipment, shall conform with the City of Boston's adopted Electrical Code.

Name of Applicant Mrs Bud Rowe Address 825 STROWA ST.

Electrical Contractor Jim Sprague & Son's Telephone No. 599-1846

Address RR #2 NAP. Q.

General Contractor Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 825 STROWA Cost of Project 400<sup>00</sup>

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New 100A Service Change \_\_\_\_\_ Re-wiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief description of work \_\_\_\_\_

Replace Service on New Pole

Site of proposed Service Entrance 100A Number of new Circuits None

Type of proposed Service Entrance \_\_\_\_\_ Underground \_\_\_\_\_ Overhead

Supply source of electric \_\_\_\_\_ (Yes or No) No

Estimated Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

GROUND-Fault CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT BRANCHED 15 AMP AND 20 AMP CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRICAL SYSTEM AND A LINE OF BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. SEE 210-K N.E.C.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING ELECTRICAL LAYOUT AND RISKER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY)

Date 6-28-79 Applicant's Signature John P. Sprague

NO. 80-79

500



CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Project Name ROWE

Address 825 STRONG ST.

City NAP State OH

Approved ✓

Violation \_\_\_\_\_

Electrical Contractor JIM SPEISER

Remarks:

Code Reference

Service relocated only from  
damaged pole to new pole

Compliance Time \_\_\_\_\_

Inspectors Signature [Signature]

Copies To: \_\_\_\_\_

White - Applicant Yellow - Engineering Pink - Electrical Inspector

