



# City of Napoleon, Ohio

## Engineering Department

255 West Riverview Avenue, P.O. Box 151  
Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., City Engineer  
Telephone: (419) 592-4010 Fax: (419) 599-8393  
[www.napoleonohio.com](http://www.napoleonohio.com)

Ronald Shafer  
1460 Thershan Drive  
Napoleon, Ohio 43545

August 24, 2011

Dear Mr. Shafer,

On Tuesday August 23, 2011, an investigation was done at your premises, 1460 Thershan Drive, Napoleon, Ohio, in response to an inquiry about the possibility of an illegal sewer connection.

Rules 9 and 26.4 of the City of Napoleon's Rules for Water and Sewer Service prohibit the discharge of any unpolluted waters such as storm water, groundwater, roof runoff, subsurface drainage, or cooling water to enter the City's sewers.

The investigation confirmed the property had no illegal sewer connections and all downspout outlets were located above the ground surface. There were two downspouts that tied into a subsurface tile in the landscaping on the East side of the house but the outlet was found at the back of the landscaping on the Northeast corner of the house on the ground surface. As of the date above, the City of Napoleon Engineering Department considers the property in compliance in regards to Rules 9 and 26.4.

If any future alterations are made to the storm or sanitary sewers, the City of Napoleon Engineering Department shall be notified prior to any work being done to ensure the continued compliance with City Water and Sewer Rules.

If you have any questions, please call our office at (419) 592-4010.

Sincerely,

Martin T. Crossland  
Staff Engineer  
City of Napoleon

Cc: Chad E. Lulfs, P.E., P.S., City Engineer  
Dr. Jon A. Bisher, City Manager