

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 0981 Date 26FEB85

Job Location 326 Union Street Valuation \$ 400.00
Address

Owner Lee Dietrich Address Route X 4
Name

Contractor Self Telephone No. 592-3442 592-2846
Address

Electric Contractor _____

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential R4 Commercial _____ Industrial _____
No. dwelling units

New Construction _____ Addition _____ Remodel _____

Brief Description of Work Service Change to X 100 Amp

ISSUED BY *Richard J. ...* DEPT. OF BUILDING & ZONING
REB

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- ~~XXXXX~~ _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- ~~XXXXX~~ _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ <u>5.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>5.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PAID
FEB 27 1985
CITY OF NAPOLEON

THE UNIVERSITY OF CHICAGO

1900

1

Faint, illegible text, possibly bleed-through from the reverse side of the page.

Faint, illegible text, possibly bleed-through from the reverse side of the page.

Faint, illegible text, possibly bleed-through from the reverse side of the page.

Faint, illegible text, possibly bleed-through from the reverse side of the page.

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 0901 Date 26 Feb 85
 Job Location 326 Union Street Valuation \$ 400.00
 Owner Lee Dietrich Address Route X 4
 Contractor Self Telephone No. 592-3442 592-2846
 Address _____
 Electric Contractor _____
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential R4 Commercial _____ Industrial _____
No. dwelling units
 New Construction _____ Addition _____ Remodel _____
 Brief Description of Work Service Change to X 100 Amp

ISSUED BY Richard J. Hayman DEPT. OF BUILDING & ZONING
Building Official REB

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>5.00</u>
LESS FEES PAID	\$ <u>0</u>
BALANCE DUE	\$ <u>5.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PAID
FEB 27 1985
CITY OF NAPOLEON

INSPECTION RECORD

UNDERGROUND		ROUGH-IN & FINA'			
Type	Date	By	Type	Date	By
PLUMBING	Sewer Connection		Drainage, W. & Vent		
	Building Sewer		Water Piping		
	Water Piping		Condensate Lines		
			Indirect Waste		
				FINAL APPROVAL	
ELECTRICAL	Floor Ducts Raceways		Rough Wiring	03/18/85	REB
	Conduits & or Cable		Conduits/ Cable	03/18/85	REB
	Grounding & Bonding	03/18/85	Service Panel Switchboard	03/18/85	REB
			Subpanels		
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer	FINAL APPROVAL	03/18/85
MECHANICAL	Refrigerant Piping		Refrigerant Piping		
	Ducts/ Plenums		Ducts/ Plenums		
			Ventilation Supply		
			<input type="checkbox"/> Exhst.	FINAL APPROVAL	
			Wall Construction	Fireplace Chimney	
BUILDING	Excavation		Crawl Space	<input type="checkbox"/> Vent <input type="checkbox"/> Access	
	Footings & Reinforcing		Floor System(s)	Special Insp Reports Rec'd	
	Sub-soil Drain		Roof System	Smoke Detector	
	Foundation Walls		Fire Wall(s)	Demolition (sewer cap)	
	Floor Slab		Roof Cover Roof Drain	Building or Structure	
	FINAL APPROVAL BLDG. DEPT		Certificate of Occupancy issued	#	

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Lee Dietrich Address RR 4
Electrical Contractor SELF Telephone No. 599-3442
592-2846
Address _____

General Contractor _____ Telephone No. _____
Address _____

Location of Project 326 UNION ST Cost of Project _____

Work Information:

Residential _____ Commercial _____ Industrial _____
No. Units _____
New _____ Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: _____

Size of proposed service entrance 100 Amp Number of new circuits _____

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric _____ (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

PERMIT NO. 0981

PERMIT FEE \$ 5.00

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service: and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 2-26-85 Applicant's Signature [Signature]

