

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Permit No.	1253			
Issued	7/23/25			
By	[Signature] Building Inspector			
Valuation	1100.00			
	Fees	Base	Plus	Total
Construction	13.00	--	--	13.00
Plumbing				
Electrical				
Heating				
Water Tap				
Sewer Tap				
Temporary Elec.				
TOTAL	13.00	--	--	13.00

Owner Name Harriet Eckfeld, Inc.
 Address Walnut St.
 Builder Name Self
 Address Same Tel. 732-1151

Lot Information:

Street No. 1 Walnut St.
 Lot --- Subdivision Fennick's 1st Subd. noted
 Lot Dimensions Varies Lot Area --- Sq. Ft. ---
 Yard Set Back: Front --- Rear ---
One Side Min 5' Side --- Side ---

Zoning "A" Intended use of Building: Construction to the side of the existing building a 11'-6" x 7'-0" tool & repair storage shed.

Building Information:

Single X Double --- Multiple --- New Construction --- Addition --- Remodel ---
 Size: Length 11'-6" Width 7' No. of Stories 1
 Floor Area: 1st Floor --- 2nd Floor --- 3rd Floor --- Basement ---
 Unfinished Attic --- Garage ---
 Foundation: Piers --- Full Basement --- Part Basement ---
Concrete Block
 Walls: Frame --- Block --- Brick --- Other ---
 Electrical: Wiring None Electric Heating --- Electrical Appliances ---
 Plumbing: Fixtures or Traps --- Warm Air Heating --- Hot Water Heating ---

Additional Information: This permit requires compliance with the attached letter No. 336-75L and made a part here-of.

Date July 29-25 Applicant Signature Harriet Eckfeld, Inc.
 Owner - Builder - Agent

Inspection Record:

Work Started	Foundations	Plumbing, Heating
Set Back, Side Lines	Plumbing (Rough In)	And Air Conditioning
Excavation	Erecting Frame	Roof
Footing	Electrical Work

Comments:

Certificate of Occupancy Issued

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

7/15/75
To Records
7/23/75

The undersigned hereby makes application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name Earnest Hatfield Jr. Address Walnut Napoleon, OH 10

Builder's Name Earnest Hatfield Jr. Address Walnut Nap OH 10 Tel. 592-3351

LOT INFORMATION: (Not required for roofing or siding job.)

Location of Project Storage shed at side of house Lot #

Subdivision ~~Richards~~ Rennecker's Sub-Div Lot Area Sq. Ft.
min 15 min 5

Yard Set Back: Front Rear Left Side
Right Side Zoning District "D"

BUILDING INFORMATION:

Single Double Multiple New Construction X

Addition Remodel Attached Garage

Detached Garage Accessory Building X Replacement

Brief Description of Work:

Size: Length 11'6" Width 7' No. of Stories 1

Floor Area: 1st Floor Sq. Ft. 2nd Floor Sq. Ft.

3rd Floor Sq. Ft. Basement Sq. Ft.

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Thickness Block Size

Walls: Frame X Block Brick Other

Specific Type of Exterior Siding 3/4 X 6 yellow pine

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO 1/4"=1'-0" SCALE. PLOT PLAN DRAWN TO 1/8"=1'-0" SCALE. On Back of paper

ESTIMATED COST OF COMPLETED PROJECT: \$100.00

DATE 7-11-75 APPLICANT'S SIGNATURE Earnest Hatfield Jr.
OWNER-BUILDER-AGENT

PLAN
Submitted
To Records
7/23/75

CITY OF NAPOLEON
Engineering Department
315 Riverway, Napoleon
NAPOLEON, OHIO 43343

DATE 7-23-75	JOB NO. Permit No. 336-75
PROJECT 12' x 7' Tool & Garden Shed	
LOCATION Walnut St.	
CONTRACTOR Hatfield	OWNER Hatfield
WEATHER _____	TEMP. ° at _____ AM ° at _____ PM
PRESENT AT SITE Addendum To Building Permit.	

TO

M. Hatfield
Walnut St.
Napoleon, Ohio

THE FOLLOWING WAS NOTED:

IF structure is built on a concrete slab provide the following to meet min. building codes:
1) Min. of 4" base course (clean grade sand, gravel, or crushed stone) + Min. thickness of 4" concrete slab. Sec. P-603
2) Provide 1/2" anchor bolts @ 8' x 1/2" and 1' from every corner. Fig No. A-3.

IF structure is built on a wood frame floor deck, then provide means of pinning structure to ground to prevent wind uplift.

COPIES TO Hatfield + one record with Permit No. 336-75

Letter No. 336-75h
FIELD REPORT
SIGNED *Shirley Harrison*
Bldg. Insp.