

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 123 EAST WASHINGTON NAPOLEON ZIP: 43545
 Business Name: HENRY CO SHERIFFS OFFICE

DEVICE INFORMATION

Type (circle one) **RP** DC VB RPDA DCDA

Manf/Model: WILKINS 975X Size: 3/4 Serial No. W004915
 Location of Device: BASMENT MECH ROOM
 Type of Test: Differential Gauge Sight Tube

Outlet valve holding RP <input checked="" type="checkbox"/> DC <input type="checkbox"/> failed RP <input type="checkbox"/> DC <input type="checkbox"/>	Reduced Pressure Assembly ↓			Pressure Vacuum Breaker	
	Double Check Valve ↓		Relief Valve ↓	Air Inlet	Check Valve
	1st Check	2nd Check			
Test Results <i>Pass</i> Date: <i>1-23-03</i>	DC _____ psi	DC _____ psi	opened at <u>3.5</u> psi	opened at _____ psi	held at _____ psi
	RP <u>9.0</u> psi	<i>OK</i>	did not open <input type="checkbox"/>	did not open <input checked="" type="checkbox"/>	leaked <input type="checkbox"/>
	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials					
Test After Repairs Date:	DC _____ psi	DC _____ psi	opened at _____ psi	opened at _____ psi	held at _____ psi
	RP _____ psi	RP _____ psi	did not open <input type="checkbox"/>	did not open <input type="checkbox"/>	leaked <input type="checkbox"/>
	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: *Douglas J. Spauldy* Certification No. 2539
 Owner/Representative Signature: *Wendy Taylor*