

6229

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419) 592-4010

Electrical Permit

Permit Number: EL2009-29

Page 1 of 1

Printed: 9/21/2009

ADDRESS: *421 Washington St. E.*

Applicant

Name: TC Quality Affordable Construction
Address: PO Box 971

Approval Date: 4/17/2009
419-636-7665

Owners

Name: Scott & Mindy Fein
Address: 421 E. Washington
St.
Napoleon, OH 43545

Phone: 419-591-6798

Contractors

Contractor Type: Builder

Name: TC Quality Affordable Construction
Address: PO Box 971

Bryan, Oh 43506

Phone: 419-636-7665

Fees and Receipts:

Number	Description	Amount
FEE2009-454	electrical	\$25.00
FEE2009-455	State 1% fee (Calc)	\$0.25
Total Fees:		\$25.25
RCPT2009-314		\$25.25
Total Receipts:		\$25.25

Electrical upgrade

APPLICANTS SIGNATURE: _____ DATE: _____

REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION

SCANNED

CITY OF NAPOLEON GENERAL PERMIT APPLICATION

THIS APPLICATION IS FOR RESIDENTAL CONSTRUCTION INCLUDING BUILDING, ELECTRICAL,
PLUMBING, MECHANICAL, DEMOLITIONS & REMODELING

DATE 4-17-09 JOB LOCATION 421 E. WASHINGTON ST
 OWNER SCOTT AND MINDY FEIN TELEPHONE # 591-6798
 OWNER ADDRESS SAME
 CONTRACTOR TO QUALITY AFFORDABLE CELL PHONE # 212-0992
 DESCRIPTION OF WORK TO BE PERFORMED REHABILITATION
 ESTIMATED COMPLETION DATE _____ ESTIMATED COST 27,635.00

Affected Floor Area (AFA): In existing structures, it is the area affected by the improvement, i.e. a new wall dividing a room (the AFA would be only the room and not all the rooms).

DESCRIPTION	FEE	TOTAL COST
Addition & Alterations Square foot in (AFA) x \$0.05 = \$ _____ + \$25.00 = \$ 25.00		
Electrical Circuits in (AFA) x \$3.00/Circuit = \$ _____ + \$25.00 = \$ _____		
Plumbing Traps in (AFA) x \$3.00/Trap = \$ _____ + \$25.00 = \$ _____		
Siding and/or Roofing	\$25.00	\$ _____
Windows/Doors	\$25.00	\$ _____
Decks	\$25.00	\$ _____
Garage and Shed over 250 SF (Detached)	\$25.00	\$ _____
Electrical Service Upgrade	\$25.00	\$ <u>25.00</u>
Water Heater	\$25.00	\$ _____
Furnace and/or AC Replacement	\$25.00	\$ _____
MBP (100.3100.46510)	Subtotal:	\$ <u>50.00</u>
(100.0000.42700) PLUS Ohio Board of Building Standards Fee + 1%		\$ <u>.50</u>

TOTAL FEE: \$ 50.50

I FULLY UNDERSTAND THAT NO EXCAVATION, CONSTRUCTION OR STRUCTURAL ALTERATION, ELECTRICAL OR MECHANICAL INSTALLATION OR ALTERATION OF ANY BUILDING STRUCTURE, SIGN, OR PART THEREOF AND NO USE OF THE ABOVE SHALL BE UNDERTAKEN OR PERFORMED UNTIL THE PERMIT APPLIED FOR HEREIN HAS BEEN APPROVED AND ISSUED BY THE CITY OF NAPOLEON BUILDING/ZONING DEPARTMENT.

I hereby certify that I am the Owner of the named property, or that the proposed work is authorized by the Owner of record and that I have been authorized by the Owner to make this application as his/her authorized agent and I agree to conform to all applicable laws of the jurisdiction. In addition, if a permit for Work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

I HEREBY ACKNOWLEDGE THAT I HAVE READ AND FULLY UNDERSTAND THE ABOVE LISTED INSTRUCTIONS.

SIGNATURE OF APPLICANT: <u>[Signature]</u>	DATE: <u>4-17-09</u>
PRINT NAME: <u>Tina Copp</u>	
BATCH # <u>20575</u>	CHECK # <u>6431</u>
DATE <u>04-27-09</u>	



CITY OF NAPOLEON



BUILDING & ZONING DEPARTMENT
255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545
Telephone: 419/592-4010 Fax: 419/599-8393
www.napoleonohio.com

ELECTRIC METER BASE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" ELECTRIC METER BASE
(Please pickup at the City Operations Garage 1775 Industrial Drive)

Permit # 2009-06

Date Issued: 5/28/2009

Job Location: 421 E. Washington.

Work Description: service upgrade

Owner: Scott Fein
Address: 421 E. Washington
Owner Phone: 419-591-6798

Contractor: Quality Affordable
Contractor Phone: 419-212-0992

Electric Service Upgrade New Service Installation:

Industrial: Commercial: Residential: 1 Phase 3 Phase

Size of Service: 100 Amps: 150 Amps: 200 Amps: 400 Amps Other

Hub Size: 1 1/4" 1 1/2" 2"

Desired Voltage: 120/240: Other: _____

Underground Service Overhead Service

Date Completed: _____ Approved By: _____

Old Meter Number: _____ New Meter Number: _____

Comments: _____

2008 National Electrical Code Changes For Residential Applications

The City of Lafayette will be enforcing all provisions of the *National Electric Code 2008 Edition* effective August 29, 2008 as required by the State of Colorado. The following are some of the significant changes that will be enforced on all permits starting August 29, 2008.

1. All 125 volt, 15 and 20 amp receptacles installed in a residence shall be listed tamper-resistant receptacles. No exceptions for receptacles on ceilings, above counters or behind appliances. NEC 406.11.
2. All receptacles in garages and unfinished basements are required to be GFCI protected. No more exceptions for garage door openers, refrigerators, freezers or sprinkler time clocks. Receptacles serving permanently installed fire alarm or security alarm panels in basements are not required to be GFCI protected. NEC 210.8.
3. All 120 volt, 15 or 20 amp branch circuits supplying outlets in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways or similar rooms shall be protected by a listed combination type arc-fault circuit interrupter (AFCI). AFCI protection is not required for kitchens, bathrooms, garages and unfinished basements. NEC 210.12.
4. In basements and garages at least one GFCI receptacle must be installed in addition to any receptacles installed for specific equipment such as fire alarm systems, sump pumps, and so forth. NEC 210.52 (G).
5. An accessible GFCI receptacle outlet is required within the perimeter of residential balconies, decks, or porches larger than 20 square feet in area. The receptacle shall be located not more than 6 ½ feet above the standing surface. NEC 210.52 (E) (3).
6. Overcurrent devices are not permitted to be located over steps of stairways, but could be located in stair landings where the minimum clearances are met. NEC 240.24 (F).
7. Equipment grounding conductors are required to be installed with all branch circuits and feeders supplying separate buildings or structures. Existing installations are allowed to remain grounded to the neutral conductor if there is no grounding conductor, no continuous metal path (metal gas pipe, metal water pipe, or metal conduit to the structure) or ground fault protected equipment in the structure. NEC 250.32 (B).
8. Where holes are bored in joists, rafters or wood members for cables or raceways, the edge of the hole must be 1 ¼" from the edge of the member or it must be protected by nail plates with a minimum thickness of 1/16 inch. NEC 300.4 (A).