

FIELD CORRECTION NOTICE

PAGE 1

LOCATION 518 E. WASHINGTON PERMIT NO. NONE ISSUED

ISSUED TO BIRGUS FITCH AND DR LECTER SHEET SHEET  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BIRGUS FITCH 518 E. WASHINGTON

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: YOU ARE HEREBY DIRECTED  
TO OBTAIN A BUILDING PERMIT FOR THIS PROJECT.

ADDITIONAL VIOLATIONS PREVIOUS A 4' HIGH FENCE WITH  
A SELF CLOSING GATE AROUND THE  
POOL IF THE HEIGHT OF THE  
SIDE WALL IS LESS THAN 4'  
ABOUT GRADE

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE June 28 1990

FIELD CORRECTION NOTICE

PAGE 1

LOCATION S18 E. WASHINGTON PERMIT NO. None ISSUED

ISSUED TO BIGLUS FITCH AND OR LESTER SHELCT  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BIGLUS FITCH SIS E. WASHINGTON

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: YOU ARE HEREBY DIRECTED TO OBTAIN A BUILDING PERMIT FOR THIS PROJECT.

ADDITIONAL VIOLATIONS PROVIDE A 4' HIGH FENCE WITH A SELF CLOSING GATE AROUND THE POOL IF THE HEIGHT OF THE SIDE WALL IS LESS THAN 4' ABOVE GRADE

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE June 28 1990

DATE 6-10-90 BY FLOOR LUTIN

FIELD CORRECTION NOTICE

LOCATION 518 E. WASHINGTON ST PERMIT NO. DOCK 1000

ISSUED TO BILLIE LITCH POOLER LEONE SHER  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO LEONE SHER C/O E. WASHINGTON

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: YOU ARE HEREBY DIRECTED  
TO OBTAIN A SWIMMING PERMIT FOR THIS POOL.

ADDITIONAL VIOLATIONS PROBABLY A 4' HIGH FENCE WITH

A 1/2" GALV. GALV. COIL AROUND THE

POOL AT THE HEIGHT OF THE

COIL (SEE DRAWING) (SEE DRAWING)

AROUND POOL

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE June 28 1990

DATE 6-20-90

FIELD CORRECTION NOTICE

PAGE 2

LOCATION S18 E. WASHINGTON PERMIT NO. \_\_\_\_\_

ISSUED TO BIRCO, FITCH AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BIRCO, FITCH S18 E. WASHINGTON

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction:

STAIR WAY TO THE DECK MAX RISER HT 8'1/2"

MIN TREAD WIDTH 9"

HANDRAIL HT 20" TO 30"

LADDING HANDRAIL HT 36"

MAX DECKLASTER PLY 6"

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE June 28, 1990

DATE 6-20-90 BY Edman HORTON

1960 2

FIELD CORRECTION NOTICE

LOCATION COS E WASHINGTON PERMIT NO. \_\_\_\_\_

ISSUED TO BIRCH HIGH 950008 619 10 1117  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BIRCH HIGH 12 1 1960

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: \_\_\_\_\_

STAIR WAY TO THE DECK MAX CLEAR HT 5'6"

ALL RECORD WORK 9"

MINOR HT 10'7 1/2"

LANDING WOOD PANEL HT 5'6"

MAX DELIVER ONLY 6"

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 12 23 1960

FIELD CORRECTION NOTICE

PAGE 2

LOCATION S18 E. WASHINGTON PERMIT NO. \_\_\_\_\_

ISSUED TO BIRGOM FITCH AND/OR WESTER SHELT  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BIRGOM FITCH S18 E. WASHINGTON

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: \_\_\_\_\_

STAIR WAY TO THE DECK MAX RISER HT. 8 1/4"

MIN TREAD WIDTH 9"

HANDRAIL HT 70" TO 34"

LANDING HANDRAIL HT 36"

MAX BALLASTER OPLY. 6"

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE JUNE 28, 1990