



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

October 26, 1984

**Mayor**  
Robert G. Heft

Mr. Gary Malone  
United Pentecostal Church  
1033 W. Washington  
Napoleon, OH 43545

**Clerk-Treasurer**  
Rita E. W. Schweinhagen

Dear Gary:

**Members of Council**  
Darel Atstermiller, President  
William Young  
Lawrence Haase  
Daneil Fox  
Donald Morford  
Lynn Wachtmann

This letter is in regard to the fire rating between the old church structure and the new and the electrical.

Within the wall of the old church structure where it abutts the new structure, there are some electric wires not in conduit. These wires will have to be put in conduit prior to closing up that wall.

**City Manager**  
Richard A. Hayward

The wall of the new structure abutting the old structure has to be a 1 hr. fire rated wall. To make the wall 1 hr. fire rated, the outside shall be covered with a 1 hr. rated material, all the way up to 2½ ft. above the roof of the old church structure. The inside may be covered with the same material or something comparable. For the outside, rated plywood is permissible. For the inside, 5/8 X rated drywall is allowed.

**Law Director**  
Keith L. Muenfeld

Fire stopping shall be provided between the fire rated area of the wall and the non-fire rated area of the wall, 2 X 4 blocking within the wall from stud to stud is permissible for fire stopping.

If you have any questions please feel free to call.

Yours truly,

Richard G. Hayman  
Building Commissioner

RGH:dd