

**City Of Napoleon**  
**FIELD SURVEY FORM**

Premises Address: 1033 W. Washington Company Name: Henry Co. Foot + Ankle  
Contact Name: Dr. Sharrer Contact Phone No: 592-3338  
Service No: 3142 Service Size: 3/4 Meter No: 47430073 Meter Size: 1" Date Installed: 9-10-97  
Type of Inspection: Initial  Follow-Up  Date of Inspection: 2-3-99 Inspector Name: Charlie  
Type of Use: Industrial  Commercial  Residential  Water Main Size: 6" System Pressure 65-75"  
Type of Service: Domestic  Fire  Combined  Any Other Water Source: Yes  No   
If Yes, Other Type: Additional City Service  Auxiliary Source  Interconnected: Yes  No   
\*\*\*\*\*

**DOMESTIC SYSTEMS**

Type of Use: Processing  Product  Potable  Sanitary  Irrigation  Limited Area Fire   
Type of Heating: Forced Air  Electric  Solar  Boilers  Chemical Treatment: Yes  No   
Type of Cooling: Cooling Tower  Chiller  Chemical Treatment: Yes  No  Direct Conn: Yes  No   
Dishwasher: Yes  No  Eductors: Yes  No  Garbage Disposal: Yes  No  Jacuzzi: Yes  No   
Swimming Pool: Yes  No  Air Gap at Supply: Yes  No  Pumps Used: Yes  No  Capacity

**INSPECTOR COMMENTS/DIAGRAMS**

*2 - bathrooms for office  
1 - bathroom for apt.  
X-Ray film Developer hooked to faucet at slop sink  
hand wash + eye wash sink in hallway  
small whirlpool filled by hose below flood rim*

**FIRE PROTECTION SYSTEMS**

System Type: Dry Spinkler  Wet Sprinkler  Dry Riser  Wet Riser  Hydrants: Yes  No   
Hydrants Self-Draining: Yes  No  Storage Provided: Yes  No  Antifreeze Legs: Yes  No   
Auxiliary Water Storage: Yes  No  Pumps Used: Yes  No  Capacity:  (GPM) Pressure:

**INSPECTOR COMMENTS/DIAGRAMS**

*Need a copy of M.S.D.S. sheets on chemicals for film Developer  
1" PCA already in place providing M.S.D.S. sheets check out O.K. The only thing you will need to do is get this device tested*

**BACKFLOW PREVENTION REQUIREMENTS**

*if expansion Tank is not in place, one will have to be installed  
to allow for expansion*