METER YOKE RELEASE

This document is for the release of one (1) Water Meter Yoke for Residential water service lines.

RELEASE NO. 160
PERMIT NO. ISSUED 8-3-95
JOB LOCATION
() - Inside City Limits () - Outside City Limits
ISSUED BY BY
OWNER Beneficial Mortgage Co. of Ohi
ADDRESS 121 W. Washington
CONTRACTOR Elling P4H
ADDRESS St. Rt. 108 Mapatron
CONTRACTOR'S PHONE NO. 598-8991
WATER TAP SIZE: () = 1" () = 1-1/2" () = 2"
WATER METER s#
() - New Dwelling () - Existing Dwelling
() - Lawn Meter Structure
Water Service Line to be Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.
Watts No.07 Dual check required (\(\sqrt{)} = Yes () = No
Water Meter Yoke installation is subject to the following conditions:
1.) Must be located in an accessible area.

- 2.) Must be in an area not subject to freezing temperatures.
- 3.) Must be eighteen inches (18") above floor level, not in crawl spaces.
- 4.) Must comply with the mounting criteria and clearances as set forth in DRAWING #04403901.