

PERMIT

City of Napoleon
255 W. Riverview
Napoleon, OH 43545

Division of Building and Zoning
PH (419) 592-4010
FAX (419) 599-8393

Permit No: 001956

Date Issued: 11-20-03

Issued by: BND

Job Location: 124 W WASHINGTON ST

Est. Cost:

Lot #:

Subdivision Name: DOWNTOWN

Owner: D.R. BRYAN COMPANIES INC.
Address: 791 FAIRWAY LANE
CSZ: WAUSEON, OH 43567
Phone: 419-335-0212

Agent: ELLING PLBG & HTG
Address: T-487 ST HWY 108
CSZ: NAPOLEON, OH 43545
Phone: 419-598-8991

Use Type – Residential:

Other:

ZONING INFORMATION

Dist:	Lot Dim:	Area:	Fyrd:	Syrd:	Ryrd:
Max HT:	# Pkg Spaces:			# Loading SP:	Max Lot Cov:

BOARD OF ZONING APPEALS:

Work Type – New:	Replmnt:	Add'n:	Alter:	Remodel:
------------------	----------	--------	--------	----------


WORK INFORMATION

Size - Lgth:	Width:	Stories:	Living Area SF:
Garage Area SF:	Height:	Bldg Vol Demo Permit:	

WORK DESCRIPTION
WATER METER UPSIZE

FEE DESCRIPTION	PAID DATE	FEE AMOUNT DUE
WATER TAP PERMIT		132.00

Total Fees Due 132.00



11/20/03
Date

David G. Beutholder
Applicant Signature

City of Napoleon Inspection Form

Permit #001956

Date Issued: 11-20-2003

Job Location: 124 W WASHINGTON ST

Owner: D.R. BRYAN COMPANIES INC.

Owner Phone: 419-335-0212

Contractor: ELLING PLBG & HTG

Contractor Phone: 419-598-8991

Work Description: WATER METER UPSIZE

Plumbing: UNDGR _____ RGHIN _____ FINAL _____

 SEWER INSP _____

Mechanical: UNDGR _____ RGHIN _____ FINAL _____

 FURNACE REPLAC _____ AIR COND _____

Electrical: UNDGR _____ RGHIN _____ FINAL _____

 SEVR UPGR _____

Building: Site _____ FTG _____ FNDDT _____

 STRU _____ ROOF _____ EXT _____

 VENT _____ ACCES _____ EGRS _____

 SMKDT _____ FINAL _____

 ISSUE TEMP OCCUP _____ ISSUE OCCUP _____

STGE Shed: SITE _____ FINAL _____

Sign: FTG _____ FINAL _____

Fence: SITE _____ FINAL _____

MISC INSP: _____

NOTES: _____

INSPECTORS INITIALS: _____

City of Napoleon

Water Meter Yoke Release Form

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" WATER METER YOKE ASSEMBLY
(Please pickup at City Operations Department 1775 Industrial Drive).

Permit #001956

Date Issued: 11-20-2003

Job Location: 124 W WASHINGTON ST

Owner: D.R. BRYAN COMPANIES INC.

Address: 791 FAIRWAY LANE WAUSEON, OH 43567

Owner Phone: 419-335-0212

Contractor: ELLING PLBG & HTG

Address: T-487 ST HWY 108 NAPOLEON, OH 43545

Phone: 419-598-8991

Water Tap Size 1" _____ 1.5" _____ 2" X Other _____

Water Meter Yoke Size 5/8" _____ 3/4" _____ 1" X Other _____

New Structure _____ Existing Structure X Lawn Meter _____

WATER SERVICE LINE TO BE TYPE "K" COPPER OR "CTS" POLYETHELENE TUBING OF 1" MINIMUM SIZE.

Backflow Device Required Yes X No _____

Type of Backflow Required: RPZ installed

Water Meter Yoke Installation is subject to the following conditions

- 1.) Must be located in an accessible area.
- 2.) Must be in an area which is not subject to freezing temperatures.
- 3.) Must be at least 18" above floor level (no crawl space installations).
- 4.) Must comply with minimum mounting requirements (drawing available)

Issued By _____ Received By _____

1 Copy to: Building Dept, Water Dept, and Utilities Dept