



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

April 30, 1991

Mayor  
Steven Lankenau

*Bischoff Company  
19 Lakeview Drive  
Napoleon, Ohio 43545*

Members of Council  
James Hershberger, President  
Terri A. Williams  
John E. Church  
Randy J. Bachman  
Dennis L. Fligor  
Robert G. Heft

*Dear Don & Doug:*

*I have again reviewed all the materials presented to me concerning the location of your stairwell at 125 1/2 West Washington and its approximate location to the electric meter on the back of the Strayer Building. I have not found an acceptable compromise in this matter and must therefore support the position of the Building and Zoning Administrator, Brent Damman, and advise he will be proceeding as he feels necessary and according to law for purposes of having you relocate the stairwell so it will not be in violation of the National Electric Code as adopted by the City of Napoleon.*

City Manager  
Terry Dunn

*Brent had at one time apparently offered to allow a 22" clearance from the electrical meter which can be accomplished by angling the stairwell slightly to the east as had once been proposed. Brent advises this should be accomplished within 30 days.*

Finance Director  
Rupert W. Schweinhagen

Law Director  
Michael J. Wesche

*Very truly yours,*

Prosecuting Attorney  
Thomas L. Bischoff

*Thomas L. Bischoff  
Prosecuting Attorney*

*TLB:skw*



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

April 15th, 1991

Mr. Douglas Bischoff  
Bischoff Company  
19 Lakeview Dr.  
Napoleon, Ohio 43545

Re. Meter clearance  
at 620 N Scott St.

Mayor  
Steven Lankenau

Members of Council  
James Hershberger, President  
Terri A. Williams  
John E. Church  
Randy J. Bachman  
Dennis L. Filgor  
Robert G. Heft

City Manager  
Terry Dunn

Finance Director  
Rupert W. Schweinhagen

Law Director  
Michael J. Wesche

Prosecuting Attorney  
Thomas L. Bischoff

Dear Douglas

This letter is to inform you that the meter clearance problem at the above property location still exists.

Mr. Strayer has indicated to the City Prosecutor that he is not willing to move the meter, therefore the new stairway must be moved so that there is three (3) feet of clearance in front of said meter.

Sincerely  
  
Brent N Damman  
Building & Zoning Admin.

06267001.01BI91/01