

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name SHONDELL JEWELERS
 Address 134 W. WASHINGTON ST.
 Builder Name COCHRAN ELECTRIC
 Address 621 SCOTT ST. Tel. _____

Permit No. 51
 Issued JANUARY 20, 1961
 By ROBERT C. JONES
 Building Inspector
 Estimated Cost _____

Lot Information:

Street No. 134 W. WASHINGTON
 Lot _____ Subdivision _____
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Fees	Base	Plus	Total
Construction			
Basement			
Detached Garage			
Plumbing			
Electrical	5.00	.65	5.65
Heating			
Air Conditioning			
Total			5.65

Building Information:

Residence _____ Commercial Industrial _____
 Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length _____ Width _____ No. of Stories 1
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical Outlets: 120v 4 240v 1
 Plumbing: Fixtures _____ Traps _____ Vents _____ Heating _____ Air Conditioning _____
 Additional Information: REWIRING FOR OUTLETS

Date 1-20-61 Applicant Signature _____
 Owner - Builder - Agent Leo Shondell Jr.

Certificate of Occupancy

Date _____

Final inspection of building construction authorized by the above Permit has been made. Construction is completed substantially in conformity with the approved plans and permission is hereby granted to occupy such building in compliance with such legal use and occupancy as may be authorized under the provisions of the zoning ordinance of the City of Napoleon.

Building Inspector

January 14, 1961

Mrs. E. Michael Hinds
304 W. Washington Street
Napoleon, Ohio

Subject: Inspection of Building at 134 W. Washington Street

Dear Mrs. Hinds:

On January 12, 1961 I made an inspection of the building at 134 W. Washington Street which is being altered for use by Shondell Jewelers.

Mr. Shondell has engaged an electrical contractor to install new lighting fixtures, but the existing asbestos insulated wiring is prohibited in a business location by the National Electrical Code which is a part of the City Building Code Ordinance No. 404. The recommended method of installing electrical wiring is to use a rigid metal conduit as a carrier for all wires. In the basement the old original wiring is run in a conduit which will pass inspection. The electrical work that has been done from time to time is the work that will have to be replaced and installed according to code.

If there are any questions you may have concerning our new building code we would be happy to answer them.

Very truly yours,
CITY OF NAPOLEON

RCJ:lg

Robert C. Jones
Building Commissioner