

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name MRS. F. H. ROESSING  
 Address 211 W. WASHINGTON ST.  
 Builder Name ARTHUR GERMAN  
 Address 128 E. MAUMEE Tel. \_\_\_\_\_

Permit No. 18  
 Issued AUGUST 5, 1960  
 By ROBERT C. JONES  
 Building Inspector

Estimated Cost \_\_\_\_\_

Lot Information:

Street No. 117 W. WASHINGTON ST.  
 Lot \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Lot Dimensions \_\_\_\_\_ Lot Area \_\_\_\_\_ Sq. Ft.  
 Yard Set Back: Front \_\_\_\_\_ Rear \_\_\_\_\_  
 Side \_\_\_\_\_ Side \_\_\_\_\_

Fees	Base	Plus	Total
Construction	10.00	1.57	11.57
Basement			
Detached Garage			
Plumbing	3.00	3.00	6.00
Electrical	5.00	4.60	9.60
Heating			
Air Conditioning			
Total			27.17

Building Information:

Residence \_\_\_\_\_ Commercial  Industrial \_\_\_\_\_  
 Single \_\_\_\_\_ Double \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel   
 Size: Length 100 Width 21 No. of Stories \_\_\_\_\_  
 Floor Area: 1st Floor \_\_\_\_\_ 2nd Floor \_\_\_\_\_ 3rd Floor \_\_\_\_\_ Basement \_\_\_\_\_  
 Unfinished Attic \_\_\_\_\_ Garage \_\_\_\_\_  
 Foundation: Piers \_\_\_\_\_ Full Basement  Part Basement \_\_\_\_\_  
 Concrete \_\_\_\_\_ Block \_\_\_\_\_  
 Walls: Frame \_\_\_\_\_ Block  Brick  Other \_\_\_\_\_  
 Electrical Outlets: 120v 46 240v \_\_\_\_\_  
 Plumbing: Fixtures 2 Traps 1 Vents \_\_\_\_\_ Heating \_\_\_\_\_ Air Conditioning \_\_\_\_\_  
 Additional Information: \_\_\_\_\_

Date 9-19-60 Applicant Signature Arthur German  
 Owner - Builder - Agent

Certificate of Occupancy

Date \_\_\_\_\_

Final inspection of building construction authorized by the above Permit has been made. Construction is completed substantially in conformity with the approved plans and permission is hereby granted to occupy such building in compliance with such legal use and occupancy as may be authorized under the provisions of the zoning ordinance of the City of Napoleon.

Building Inspector

August 10, 1960

Mr. Arthur Germann  
7 Pontious Place  
Napoleon, Ohio

SUBJECT: Violation of Ordinance No. 404  
Building Code

Dear Mr. Germann:

On August 9, 1960 I made an inspection of the building at 117 W. Washington Street which is being remodeled by your company. In talking with your electrician on the job, he stated that some of the existing asbestos insulated conductors were to be used in the basement. The use of this type of conductor is prohibited in a business location by the National Electrical Code which is a part of Ordinance No. 404. The recommended method is to use a rigid metal conduit as a carrier for all conductors.

If there are any questions you or the owner of the building may have concerning our new building code we would be happy to answer them.

Thank you.

Very truly yours,

CITY OF NAPOLEON

RCJ:lg

Robert C. Jones  
Building Commissioner

C  
O  
P  
Y