



City of Napoleon, Ohio

Engineering Department

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., City Engineer

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

July 15, 2010

Donald Moore
590 Becklee Drive
Napoleon, OH 43545

Re: 409 W. Washington Street
Sanitary Sewer Connection

Dear Mr. Moore,

During the W. Washington Street & Avon Place Improvements project, the City of Napoleon discovered that the existing sanitary sewer services for 403, 409, & 411 W. Washington Street were all connected into one (1) sanitary sewer service. Per Rule 10.1 (E) of the City of Napoleon Rules for Water and Sewer Service, "A separate and independent building sewer shall be provided for every building..."

To come into compliance with this rule, you are hereby given notice that the sanitary sewer services for 403 & 411 W. Washington Street must be removed from the sanitary sewer service for 409 W. Washington Street. Although the sanitary sewer service for 409 W. Washington Street does not require relocation, the work required to relocate the other two (2) sanitary sewer services may require excavation on the property located at 409 W. Washington Street. All work must be completed within sixty (60) days from the date of this letter. The cost of this work shall be the responsibility of the affected property owners.

Failure to comply with this notice shall constitute a violation of Rule 27 (E) of the City of Napoleon Rules for Water and Sewer Service, "...the City may seek a civil injunction and abatement from a court of competent jurisdiction; further, violations of any water or sewer Rule ... will be just cause for termination of service."

All corrective work performed must be per the City of Napoleon's standards. All specifications, permits, and inspections must be obtained from the City of Napoleon's Engineering Department. All information regarding the location and depth of the new sanitary sewer laterals provided for the affected properties can also be obtained from the City of Napoleon's Engineering Department. The Engineering Department may be reached at 419-592-4010 between 7:30 a.m. and 4:00 p.m. We appreciate your attention to this matter.

Yours truly,

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

cc: Dr. Jon A. Bisher, City Manager
David Grahn, City Law Director
Jeff Marihugh, Operations Superintendent