

June 19, 2012

Steve Lankenau
539 W. Washington
Napoleon OH 43545

Chad Lulfs
City of Napoleon
255 Riverview
Napoleon OH 43545

Re: Illegal Sewer Connections

Dear Mr. Lulfs:

In response to your letter of June 18, to the best of our knowledge, we have no illegal sewer connections. Please contact me (419.784.6291) and we can discuss the connection which you feel is a violation.

Thank you.

Sincerely,

A handwritten signature in blue ink, appearing to be 'SL', with a horizontal line extending to the right.

Steve Lankenau

cc: Jon Bisher
Trevor Hayberger
Jeff Lankenau



City of Napoleon, Ohio

Department of Public Works

255 West Riverview Avenue, P.O. Box 151
Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works
Telephone: (419) 592-4010 Fax: (419) 599-8393
www.napoleonohio.com

June 22, 2012

539 W. Washington Street
Napoleon, Ohio 43545

Attn: Steve Lankenau

Re: Illegal Sewer Connections

Dear Mr. Lankenau,

I received your letter dated June 19, 2012 which stated that you do not believe there are any illegal sewer connections at the above address. Our initial field review found illegal connections on the northwest side and corner. After receiving your letter, I performed a second field review of the property. I found two (2) connections which appear to be in violation of the City's rules. The ground pipe at the northwest corner of the house must be removed to two (2) feet below grade and permanently capped. A second connection into the ground was found on the west side of the house. This downspout must be disconnected and the ground pipe removed to two (2) feet below grade and permanently capped. Please see the enclosed sketch.

As stated in the original letter addressing this issue, all work must be performed in accordance with the City's specifications. All work must also be inspected by the City of Napoleon's Engineering Department. If you have any questions or require additional information, please contact our office.


Yours truly,

Chad E. Lulfs, P.E., P.S.
Director of Public Works
City of Napoleon

cc: Dr. Jon A. Bisher, City Manager

Encl.

Chad,
Please give
me a call to
discuss.



- 1. Ground Pipe
- 2. Connected Downspout

