



SCANNED

DATE: 7-26-12
INSPECTED BY: MARTY CROSSLAND
INVESTIGATION OF ILLEGAL DOWN-
SPOUT CONNECTIONS AT 543 W.
WASHINGTON. ALL DOWNSPOUTS
ARE IN COMPLIANCE OR WERE
APPROVED PREVIOUSLY. OLD TILES
WILL NEED CAPPED OFF OR
CEMENTED SHUT.