

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Norman Bair

Address 618 W. Washington St.

Builder Name Self

Address Same Tel. 599-0486

Lot Information:

Street No. 618 W. Washington St.

Lot 40 Subdivision Sheffield's 2nd Add

Lot Dimensions Lot Area Sq. Ft.

Yard Set Back: Front Rear

Side Side

Zoning "B" Intended use of Building: Installing on the existing

Accessory Building (barn) new 200AMP service with the main disc. below the meter, and installing within the existing dwelling a new 100AMP disc. switch.

Building Information:

Single Double Multiple New Construction Addition Remodel X

Size: Length Width No. of Stories 2

Floor Area: 1st Floor 2nd Floor 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical: Wiring 200AMP Electric Heating Electrical Appliances

Plumbing: Fixtures or Traps Service Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the approved plans and the attached addendum marked exhibit "A" and made a part here-of.

Date Nov. 6, 1975 Applicant Signature Norman Bair

Mailing Address: 907 Lynn St.

Owner - Builder - Agent

Note: 11/20/75 Re-inspected & approved by Howes.

Inspection Record:

Work Started Foundations Plumbing, Heating

Set Back, Side Lines Plumbing (Rough In) And Air Conditioning

Excavation Erecting Frame Roof

Footing Electrical Work 11/6/75 Disapproved by Howes

Comments:

Certificate of Occupancy Issued

Pink - Engineer

Inspector

Permit No. 104-75

Issued 10/10/75

By Thomas W. Brennan
Building Inspector

Valuation \$100.00

Fees	Base	Plus	Total
Construction
Plumbing
Electrical	<u>\$3.00</u>	<u>\$4.75</u>	<u>\$7.75</u>
Heating
Water Tap
Sewer Tap
Temporary Elec.
TOTAL	<u>\$3.00</u>	<u>\$4.75</u>	<u>\$7.75</u>

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name NORMAN BAIR

Address 612 W. Washington St

City Napoleon State OHIO

Approved Complied 11-20-75

Violation

Electrical Contractor

Sent To Bair Paul 11/10/75

Date 11-6-75

Permit No. 404-75

Type of Inspection ELECT. ROUGH

Type of Occupancy

Remarks:

Code Reference

- ① Bare ground wires are not to connected to the neutral bus bars in panel boards down stream from service equipment Art-384-27 NEC
- ② Cables run through bored holes in wood framing shall be at the approx. center of the face of a member or not less than 1 1/2 inches from the nearest edge. Art-300-4(a1)
- ③ Bored bushings shall be used on service entrance conductors Art-250-72(d)
- ④ Where portions of an interior raceway is exposed to widely different temperatures a vapor seal must be used. Art-300-7(a)
- ⑤ Absence of metal raceway from "LB" conduit to metal bed. Art-300-10

Approved by Norman Howes 11/22/75

Compliance Time Prior to Perm. Conn.

Inspectors Signature Norman Howes

Copies To:

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 11-6-75

Permit No. 404-75

Type of Inspection Elect. Rough

Type of Occupancy

Project Name Sherman Bair

Address 618 W Washington St

City Napoleon State OHIO

Approved Completed 11-20-75

Violation Electrical Contractor

Remarks:	Code Reference
② An oxidizing inhibitor must be used on chem. terminations.	Art-110-14 NEC
⑦ In damp or wet locations boxes & fittings must be suitable for the conditions, gasket on "L.B."	Art-370-5 NEC
⑧ Grounding electrodes shall be corrosion resistant to assure positive grounding of electrical systems.	Art-250-83 NEC
⑨ Use insulating bushings on raceways where conductors #4 and larger enter the raceways.	Art-373-6 (C)

Compliance Time Prior to Power Conn. Inspectors Signature Norman Howe

Copies To:

Norman Howes
222-2234

Because applicant did not indicate
total number of new circuits
I will base fee on average
cost of new services

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

Know large old location *AWP*

1-75 for 10 circuits
6.00 for 10 more @ 60¢
7.75 *AWP*

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Norman Bain Address 618 W Washington St

Contractor's Name Norman Bain Address 618 W Washington Tel. 599 0486

LOT INFORMATION:

Location of Project Home Zoning District A-B

Lot 40 Sheffield's 2nd Add.

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing Addition _____

Replacement _____ Remodel _____ Service Change

Size: Total Square Foot Per Floor 900-1000-500 No. of Stories 2

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only Yes (Yes or No)

Total Number of New Circuits House NWE Total Number of New Circuits Garage
Excluding Appliance Circuits 2

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range Gas Range Hood No Clothes Dryer Gas Dishwasher X

Air Conditioner 110V Attic Fan Blower No Room Exhaust Fan No

Disposal No Hot Water Heater Gas Electric Oven Gas


Require Temporary Electric No (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.



APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: 350.00 - 400.00

DATE 10-6-25 APPLICANT'S SIGNATURE Norman Bain
OWNER-CONTRACTOR-AGENT




Norman Blair
615 WASHINGTON





5

0

0



BY DATE 10/17/10
PLAN APPROVAL
10/17/10



October 10, 1975

Mr. Norman Bair
618 W. Washington St.
Napoleon, Ohio 43545

Ref: Accessory Building - Located in
"B" Residential" Zone.

Dear Mr. Bair:

So that there is no misunderstanding, I would like to take this time to explain a certain section of the City of Napoleon Zoning Ordinance 1104, Section 85.44 (Home Occupations). I am sure you'll pass this information on to any other interested party.

Home Occupations, such as making or repairing furnishings or crafts for sale is permitted only within 25% floor area of the primary building or dwelling unit used as a residence. No home occupation shall be conducted in any accessory building. The barn the new 200 amp electrical service entrance is going to be installed upon is classified an accessory building.

If you have any questions, please feel free to contact me at the City Building or call phone number 592-4010.

Very truly yours,

Thomas W. Terranova
Building & Zoning Inspector
Engineering Department

TWT/cv