

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Max Jeffers
 Address 755 W. Washington St.
 Builder Name Cochran Electrical Co.
 Address 525 N. Perry St. Tel. 592-0891

Lot Information:

Street No. 755 W. Washington St.
 Lot 55 Subdivision Sheffield's 2ND
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning "B" Intended use of Building: Installing in the same location as the existing, new 100AMP. overhead service entrance, service equipment in basement and adding appliance circuit's for range and clothes dryer.

Building Information:

Single Double _____ Multiple _____ New Construction _____ Addition _____ Remodel
 Size: Length _____ Width _____ No. of Stories 2
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring 100AMP. Electric Heating _____ Electrical Appliances X (2)
 Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____

Additional Information: _____

Date 3-10-76 Applicant Signature [Signature]
 Owner - Builder - Agent

Permit No.	<u>172-76</u>			
Issued	<u>3/9/76</u>			
By	<u>Thomas W. Brennan</u> Building Inspector			
Valuation	<u>\$250.00</u>			
	Fees	Base	Plus	Total
Construction	---	---	---	---
Plumbing	---	---	---	---
Electrical	<u>\$3.00</u>	<u>\$3.75</u>	<u>\$6.75</u>	<u>\$6.75</u>
Heating	---	---	---	---
Water Tap	---	---	---	---
Sewer Tap	---	---	---	---
Temporary Elec.	---	---	---	---
TOTAL	\$3.00	\$3.75	\$6.75	\$6.75

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work 4/15/76 SERVICE AND PANEL INSPECTED AND APPROVED BY HOWES.

Comments: 4/15/76 HOWES INFORMED METERS SPICING OF GROUND WIRE NOT PERMITTED AWF.

Certificate of Occupancy Issued _____

Pink - Engineer

Inspector

Date: 3/9/76

TO: Electric Distribution Superintendent
FROM: The Building Inspector - Engineering Dept.

Please confirm the installation of 100 AMP. electrical service entrance, located @ same location of existing (Please inform if closer than 3' to any opening) at the following address: 755 W. Washington St.

Approved _____

Not Approved _____

K. Chang
Electric Supt.

3-9-76
Date

Remarks: No such address.

749-755

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings. *check address*

Owner's Name MAX JEFFERS Address 755 W WASHINGTON ST

Contractor's Name COCHRAN ELECT. Address 525 N PERRY Tel 592-0891

LOT INFORMATION:

Location of Project Lot 55 Sheffield's 2nd Zoning District "B"

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing Addition _____

Replacement Remodel _____ Service Change

Size: Total Square Foot Per Floor _____ No. of Stories _____

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only YES (Yes or No)

Total Number of New Circuits 2 Total Number of New Circuits Excluding Appliance Circuits 2

APPLIANCE CIRCUITS: (indicate quantity) *\$ 2.00 base*
\$ 2.00 Appl
\$ 1.75
\$ 6.75 Total
Electric Range Range Hood _____ Clothes Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric NO (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$ 250⁰⁰

DATE 3-8-76 APPLICANT'S SIGNATURE Bryan Myers
OWNER-CONTRACTOR-AGENT