

City Of Napoleon

FIELD SURVEY FORM

Premises Address: 1015 Welsted Company Name: Nickle's Bakery
Contact Name: Doug Helmke Contact Phone No: 599-4381
Service No: 2487 Service Size: 1" Meter No: 4207111 Meter Size: 1" Date Installed: 2-15-96
Type of Inspection: Initial Follow-Up Date of Inspection: 6-9-98 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 4" System Pressure 65-75psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

2 - hose bibbs
3 - sinks
2 - stools
1 - water heater

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: (GPM) Pressure:

INSPECTOR COMMENTS/DIAGRAMS

nothing found here w/high degree of hazards

BACKFLOW PREVENTION REQUIREMENTS

Double Check Valve Assembly
Device must be installed in horizontal position