

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 146 Date Oct. 10, 1980
Job Location 900 Westmont Valuation \$ 350.00
Owner William H. Beech Address 900 Westmont
Contractor William H. Beech Telephone No. 592-6237
Address 900 Westmont, Napoleon, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential Commercial _____ Industrial _____
New Construction _____ Addition _____ Remodel _____
Brief Description of Work New 200 amp service on house and 4 circuits in garage with subpanel

ISSUED BY Richard J. Hayman DEPT. OF BUILDING & ZONING
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>17.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ <u>17.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>17.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name WILLIAM H. BEECH Address 900 Westmont Ave

Electrical Contractor WILLIAM H. BEECH Telephone No 592 6237

Address _____

General Contractor _____ Telephone No. ~~8352~~

Address _____

Location of Project _____ Cost of Project \$350,00

Work Information:

Residential 1 Commercial _____ Industrial _____

New YES Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: New 200 amp service on house and 4 circuits in garage with subpanel.

Size of proposed service entrance 200 AM Number of new circuits 12

Type of proposed service entrance _____ Underground _____ Overhead YES

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*GROUND FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 and 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE: AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 10-7-80 Applicant's Signature William H. Beech

PERMIT NO.

PERMIT FEE \$

17.00

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

106

Permit No. _____ Date Oct. 10, 1980

Job Location 900 Westmont Valuation \$ 350.00

Owner William H. Beech Address 900 Westmont

Contractor William H. Beech Name Address Telephone No. 592-6237

Address 900 Westmont, Napoleon, Ohio

Electric Contractor _____

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential X No. dwelling units Commercial _____ Industrial _____

New Construction _____ Addition _____ Remodel _____

Brief Description of Work New 200 amp service on house and 4 circuits in garage with subpanel.

ISSUED BY _____ Building Official DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- X _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>17.00</u>
Plumbing Permit	\$ <u>PAID</u>
Mechanical Permit	\$ _____
Demolition Permit	\$ <u>OCT 10 1980</u>
Zoning Permit	\$ _____
Sign Permit	\$ <u>CITY OF NAPOLEON</u>
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>17.00</u>
LESS FEES PAID	\$ <u>17.00</u>
BALANCE DUE	\$ _____

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

9/25/81 No ground wire

INSPECTION RECORD

UNDERGROUND		ROUGH-IN			FINAL	
Type	Date	By	Type	Date	By	Date
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent
	Building Sewer		Water Piping			Water Heater
	Water Piping		Condensate Lines			Backflow Prevention
			Indirect Waste			
ELECTRICAL	Floor Ducts Raceways		Rough Wiring			FINAL APPROVAL
	Conduits & Cable		Conduits/Cable			Signs
	Grounding & Bonding		Service Panel			Electric Mtr. Clearance
			Subpanels			
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Duct Insulation
	Ducts/Plenums		Ducts/Plenums			Chimney(s)
			Ventilation Supply			Furnace(s)
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL
BUILDING			<input type="checkbox"/> Exhst.			FINAL APPROVAL
	Location, Set-backs, Esmt(s)		Wall Construction			Fireplace Chimney
	Excavation		Crawl Space			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access
	Footings & Reinforcing		Floor System(s)			Special Insp Reports Rec'd
	Sub-soil Drain		Roof System			Smoke Detector
	Foundation Walls		Fire Wall(s)			Demolition (sewer cap)
	Floor Slab		Roof Cover			Building or Structure
			Roof Drain			
FINAL APPROVAL		Certificate of Occupancy Issued		#		

JFC 8-25-81

Grounds OK

checked entry in conduit.

OK