

✓

City of Napoleon Villas of Briarheath

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 860 Westmoreland Zip: 43545
 Business Name: Fox Gate Farms 328 S. Main Bowling Green, Oh 43402
 Contact Person: Nova Zimmerman Title: Sales Director
 Phone Number: 599-1253 Date of Test: 3-14-00

DEVICE INFORMATION

Type (circle one) **RP** **DC** **VB** **RPDA** **DCDA**
 Manf/Model: Watts 2000B Size: 3/4 Serial No.: 09340
 Location of Device: East wall of office trailer

Type of Test. Differential Gauge Sight Tube

Outlet Valve	Reduced Pressure Assembly		Pressure Vacuum Breaker		
	Double Check Valve		Relief Valve	Air Inlet	Check Valve
Holding <input type="checkbox"/>					
Failed <input type="checkbox"/>	1st Check	2nd Check			
Test Results <u>fail</u>	DC _____ psi <u>NOT Holding</u> <u>Apparent</u>	DC _____ psi	Opened at _____ psi	Opened at _____ psi	Held at _____ psi
	RP _____ psi <u>Actual</u>		Did Not Open <input type="checkbox"/>	Did Not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Date: <u>3-14-00</u>	Pass <input type="checkbox"/> Failed <input checked="" type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials	<u>Cleaned out device had a stone inside</u>				
Test After Repairs <u>pass</u>	DC <u>10</u> psi	DC <u>10</u> psi	Opened At _____ psi	Opened At _____ psi	Held At _____ psi
	RP _____ psi	RP _____ psi	Did Not Open <input type="checkbox"/>	Did Not Open <input type="checkbox"/>	Leaked <input type="checkbox"/>
Date: <u>3-14-00</u>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: Donnie D. Br... Certification No. 528
 Owner/Representative Signature: Mark Walker