

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Henry A. Nienkerk

Address 115 Highland

Builder Name .....

Address ..... Tel. 592-8820

Lot Information:

Street No. 125 Westwood Ave

Lot 32 Subdivision .....

Lot Dimensions ..... Lot Area 11230 Sq. Ft.

Yard Set Back: Front ..... Rear .....

Side 12 Side 15

Sidewalk required in accordance with Ordinance No. .....

Building Information:

Residence ..... Commercial ..... Industrial .....

Single ..... Double ..... Multiple ..... New Construction ..... Addition ..... Remodel .....

Size: Length 14 Width 32 No. of Stories .....

Floor Area: 1st Floor 1877 2nd Floor ..... 3rd Floor ..... Basement .....

Unfinished Attic ..... Garage .....

Foundation: Piers ..... Full Basement ..... Part Basement .....  
Concrete ..... Block .....

Walls: Frame ..... Block ..... Brick ..... Other .....

Electrical Outlets: 120v 33 240v 2

Plumbing: Fixtures ..... Traps 3 Vents ..... Heating ..... Air Conditioning .....

Additional Information: .....

Date ..... Applicant Signature .....

Inspection Record:

Work Started ..... Foundations ..... Plumbing, Heating .....

Set Back, Side Lines ..... Plumbing (Rough In) 2-11-74 And Air Conditioning .....

Excavation ..... Erecting Frame ..... Roof .....

Footing 10-22-73 1 1/2 C yds Electrical Work 7/11/74

Comments: .....

Certificate of Occupancy Issued ON 3/21/75, No. 022 by Thomas W. Brennan

Pink - Engineer

Inspector

Permit No. .....

Issued .....

By .....  
Building Inspector

Estimated Cost 29114

Fees	Base	Plus	Total
Construction	500	736	1236
Basement			
Detached Garage			
Plumbing	30	25	55
Electrical	300	330	630
Heating	12		12
Air Conditioning			
Water Tap	200		200
Sewer Tap	44		44
Temporary Electric	12		12
Total			344

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date 3-13-75

Permit No. 101-73

Type of Inspection Final

Type of Occupancy Res. Sing.

Project Name WIEMKEN, H.

Address 115 HIGHLAND

City NAPOLEON State OHIO

Approved X

Violation See Below

Electrical Contractor J. SPICER

Remarks:

Code Reference

- 1 - Receptacles in Kitchen not in Comp with NEC-71
- 2 - Furnace 25KW + 3.7 for motor. 210-22
- 3 - Illumination for Laundry Rm. 420-2(h) Also Item C
- 4 - Grounding - 220-2(a)
- 250-81

Note: Item No. 194 only to be taken in consideration for all future construction. P.H.P.

Corrected & inspected by N. Howes 3/21/75

Compliance Time 10 days from 3-15-75 Inspectors Signature Howes

Copies To: H. Wiemken

White - Applicant Yellow - Engineering Pink - Electrical Inspector

APPLICATION FOR PERMIT TO TAP SEWER

No. 620 Date 10-5-73, 19 73  
Name Henry A. Wiemben  
Address 115 Highland

LOCATION OF CONNECTION

Street and Number 125 Westwood Ave.  
Lot No. 38 Addition Harmony Area  
Date work will start \_\_\_\_\_ (All work must be inspected)  
Work will be done by \_\_\_\_\_

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Date 10-2-73 Applicant \_\_\_\_\_  
Address \_\_\_\_\_  
Permit Fee \$60.00 Rupert W. Schweinhagen J.C.  
pd-10-2-73 Certification by City Clerk

Work Inspected \_\_\_\_\_  
Work Completed \_\_\_\_\_  
Remarks \_\_\_\_\_

APPLICATION FOR PERMIT TO TAP SEWER

No. 620 Date 10-5, 19 73

Name Henry A. Wiemken

Address 115 Highland

LOCATION OF CONNECTION

Street and Number 125 Westwood Ave

Lot No. 38 Addition Harmony Acres

Date work will start \_\_\_\_\_ (All work must be inspected)

Work will be done by \_\_\_\_\_

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Applicant \_\_\_\_\_

Date 10-2-73 Address \_\_\_\_\_

Permit Fee \$60.00 Rupert W. Schweindgen J.C.  
pd-10-2-73 Certification by City Clerk

Work Inspected \_\_\_\_\_

Work Completed \_\_\_\_\_

Remarks \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_