

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name

Address

Builder Name

Address Tel.

Lot Information:

Street No. 115 Westwood Ave.

Lot #20 Subdivision 44

Lot Dimensions 40x121 Lot Area 2100 Sq. Ft.

Yard Set Back: Front 25 Rear 49

Side 30X Side 125

Sidewalk required in accordance with Ordinance No.

Building Information:

Residence Commercial Industrial

Single Double Multiple New Construction Addition Remodel

Size: Length 50'-11" Width 36'-10" No. of Stories

Floor Area: 1st Floor 1224 sq ft 2nd Floor 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical Outlets: 120v 50 240v 2

Plumbing: Fixtures Traps 7 Vents Heating Air Conditioning

Additional Information:

Date 1-7-74 Applicant Signature

Owner - Builder - Agent

Inspection Record:

Work Started Foundations Plumbing, Heating

Set Back, Side Lines Plumbing (Rough In) 2-26-74 Above Floor And Air Conditioning

Excavation Erecting Frame Roof

Footing 14 cu yds 1-31-74 Electrical Work Final tested & approved by N. Howes 2/20/74

Comments: House sewer 76' Long 4-23-74

Certificate of Occupancy Issued 1/7/75 No. 005 by P. U. P.

Pink - Engineer

Inspector

Permit No.

Issued 1-7-74

By [Signature] Building Inspector

Estimated Cost

	Fees	Base	Plus	Total
Construction				
Basement				
Detached Garage				
Plumbing				
Electrical				
Heating				
Air Conditioning				
Water Tap				
Sewer Tap				
Temporary Electric				
Total				

Tap

CITY OF NAPOLEON

Engineering Department
255 Riverview Avenue
- NAPOLEON, OHIO 43545

DATE Dec. 18, 1974	JOB NO. Permit No. 1-74
PROJECT New One Family Dwelling	
LOCATION 165 Westwood Ave. Lot # 40	
CONTRACTOR Blue Ridge Homes	OWNER Don Westhoven
WEATHER _____	TEMP. _____ °at AM _____ °at PM
PRESENT AT SITE Tom Terranova - Bldg. Inspector Norman Howes - Elect. Inspector	

TO

Don Westhoven & Sons
135 W. Washington St.
Napoleon, Ohio, 43545

THE FOLLOWING WAS NOTED:

On Dec. 12, 1974 during Final Inspection and requires correcting before an "Certificate of Occupancy" may be issued.

- 1) Provide bonded bushing at main panel conduit to service entrance, Art. 250-72 NEC.
- 2) Within main panel provide vapor seal for conduit between service and main panel, Art. 300-6 NEC.
- 3) Under floor wiring not properly supported.
- 4) Install switch **Completed 12-20-74 P.W.F.** in garage near exit door.
- 5) Both bathroom exhaust fans must be directly vented to outside. Will except the use of one duct for both fans. Sec. R-204, One, Two and Three Family Code.
- 6) Must provide any one of the three approved methods for handling storm water from leaders and gutters.
- 7) Must vent clothes dryer duct directly to outside.
- Please contact the Engineering Dept. for re-inspection.

Final tested & approved by Miller

TO Don Westhoven, and on
1 with bldg. permit No. 1-74 No. 005

FIELD REPORT

SIGNED Norman W. Howes
City Building Inspector

No. 639 Date 1-8 1974
Name Don Westhoven & Sons
Address 135 W. WASHINGTON

LOCATION OF CONNECTION

Street and Number 165 Westwood Ave.
Lot No. 40 Addition Harmony Acres
Date work will start _____ (All work must be inspected)
Work will be done by _____

I certify that the sewer will be used only as indicated and no other drainage will be connected.

pd 1-7-74

Applicant _____

Date 1-7-74

Address _____

Demo Fee 60⁰⁰
Bldg permit # 1

Rupert W. Schweinhagen J.C.
Certification by City Clerk

Work Inspected _____

Work Completed _____

Remarks _____

639

Date 1-8 1974

Name Don Westhaver & Sons

Address 135 W. WASHINGTON

LOCATION OF CONNECTION

Street and Number 165 Westwood Ave.

Lot No. 40

Addition Harmony Acres

Date work will start (All work must be inspected)

Work will be done by

I certify that the sewer will be used only as indicated and no other drainage will be connected.

pd 1-7-74

Applicant

Date 1-7-74

Address

Permit Fee 60.00
Bldg permit # 1

Rupert W. Schweinhagen J.C.
Certification by City Clerk

Work Inspected

Work Completed

REMARKS