


Added second cleanout
since one at the house
is a wye. They also
replaced a small section
of clay pipe that was left
between original cleanout and
main.



1' = 20'
J. Hillis
5-9-2022
Insp. By: A. Dell