

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**  
**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

Permit No. 419

Date MARCH 31, 1982

Job Location 1139 WILLARD ST.  
Address

Valuation \$ 1200<sup>00</sup>

Owner RANDALL NEMIRE  
Name

Address 1139 Willard

Contractor OWNER

Telephone No. 592-7322

Address \_\_\_\_\_

Electric Contractor OWNER

Plumbing Contractor \_\_\_\_\_

Mechanical Contractor \_\_\_\_\_

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**Work Information:**

Residential SINGLE FAMILY Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units

New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel \_\_\_\_\_

Brief Description of Work NEW 100 AMP SERVICE AND REWIRE OF ENTIRE HOUSE

ISSUED BY Richard G. Hayman  
Building Official

DEPT. OF BUILDING & ZONING

**It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:**

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

**PERMIT & FEES**

Building Permit	\$ _____
Electrical Permit	\$ <u>18.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____

TOTAL FEES \$ 18.00

LESS FEES PAID \$ \_\_\_\_\_

BALANCE DUE \$ 18.00

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**

**PAID**

**MAR 31 1982**

**CITY OF NAPOLEON**



# PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING  
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 319 Date MARCH 31, 1982  
Job Location 1139 WILLARD ST. Valuation \$ \_\_\_\_\_  
Owner RANDALL NEMIRE Address 1139 Willard  
Contractor OWNER Name \_\_\_\_\_ Address \_\_\_\_\_ Telephone No. 592-7322  
Address \_\_\_\_\_  
Electric Contractor OWNER  
Plumbing Contractor \_\_\_\_\_  
Mechanical Contractor \_\_\_\_\_

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

### Work Information:

Residential SINGLE FAMILY Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
Brief Description of Work NEW 100 AMP SERVICE AND REWIRE OF ENTIRE HOUSE

ISSUED BY \_\_\_\_\_ DEPT. OF BUILDING & ZONING  
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- \_\_\_\_\_ Footing excavation prior to placing concrete.
- \_\_\_\_\_ Footing drains and foundation prior to backfill.
- \_\_\_\_\_ Prepared sub-grade prior to placing concrete floor slab.
- \_\_\_\_\_ Sanitary sewer
- \_\_\_\_\_ Rough-in electrical, plumbing and service framing prior to installing wall board.
- \_\_\_\_\_ Final electrical, plumbing and heating.
- \_\_\_\_\_ Final building inspection, prior to occupancy.

### PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>18.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ <u>18.00</u>
LESS FEES PAID	\$ <u>18.00</u>
BALANCE DUE	\$ <u>PAID</u>

Not valid until all fees are paid in full, and shall not be started within six months of date

MAR 31 1982  
CITY OF NAPOLEON

# INSPECTION RECORD

UNDERGROUND		ROUGH-IN & FINAL			
Type	Date	By	Type	Date	By
<b>PLUMBING</b>	Sewer Connection		Drainage, W. & Vent		
	Building Sewer		Water Piping		
	Water Piping		Condensate Lines		
			Indirect Waste		
<b>ELECTRICAL</b>	Floor Ducts Raceways		Rough Wiring	11/18/82	
	Conduits & Cable		Conduits/Cable		
	Grounding & Bonding	11/18/82	Service Panel Switchboard		
			Subpanels		
<b>MECHANICAL</b>	Refrigerant Piping		Refrigerant Piping		
	Ducts/Plenums		Ducts/Plenums		
			Ventilation Supply		
			<input type="checkbox"/> Exhst.		
<b>BUILDING</b>	Location, Set-backs, Esmt(s)		Wall Construction		
	Excavation		Crawl Space		
	Footings & Reinforcing		<input type="checkbox"/> Vent <input type="checkbox"/> Access		
	Sub-soil Drain		Floor System(s)		
	Foundation Walls		Roof System		
			Fire Wall(s)		
	Floor Slab		Roof Cover/ Roof Drain		
	FINAL APPROVAL BLDG. DEPT.		Certificate of Occupancy Issued		#

CITY OF NAPOLEON

BUILDING & ZONING INSPECTION DEPARTMENT

FIELD CORRECTION NOTICE

LOCATION 1139 WILLARD PERMIT NO. 419

ISSUED TO RANDALL NEMIRE  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO \_\_\_\_\_

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

- The following orders are hereby issued for their correction:
- #1 Service mast shall extend 8 ft above the roof edge the run along.
  - #2 Masts when passing thru roof over hangs shall be 2" minimum conduit of metal.
  - #3 All service entrance cables, shall be connected into the meter socket before Electric Co. changes service over.
  - #4 All grounding wires shall be in place before service is changed.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

#5 Service neutral shall be designated by a white tape at both ends when the cable is not white.  
ON OR BEFORE \_\_\_\_\_

DATE 3/31/82

BY Richard D. Hayman  
INSPECTOR

FIELD COPY



CITY OF NAPOLEON

BUILDING & ZONING INSPECTION DEPARTMENT

FIELD CORRECTION NOTICE

LOCATION 1134 WILLARD PERMIT NO. 419

ISSUED TO RANDALL NEMIRE  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO \_\_\_\_\_

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: <sup>#1</sup> Service mast shall extend

8 ft above the roof edge the run along.

<sup>#2</sup> Masts when passing thru roof overhangs shall be 2" minimum conduit of metal.

<sup>#3</sup> All service entrance cables, shall be connected into the meter socket before Electric Co. changes service over.

<sup>#4</sup> All grounding wires shall be replace before service is changed.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

<sup>#5</sup> Service mast shall be designated as a whole off at both ends when the cable is not in place.

DATE 3/31/82

BY Richard G. Hayman  
INSPECTOR

FILE COPY





CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Randall P. NEMIRE Address 1139 Willard St

Electrical Contractor NOBODY Telephone No. 592-7322

Address \_\_\_\_\_

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project Highland Division Cost of Project \$500.00

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

No. Units \_\_\_\_\_  
New  Service Change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: A complete rewiring of the whole house.

Size of proposed service entrance 100 Amp Number of new circuits 13

Type of proposed service entrance G.E. Underground \_\_\_\_\_ Overhead

Require Temporary Electric \_\_\_\_\_ (Yes or No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft

Additional Information: \_\_\_\_\_

PERMIT NO. 419  
PERMIT FEE \$ 18.00

\*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

\*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 3-23-82

Applicant's Signature Randall P. Nemire



- 1) Range on - 40 amp Circuit
- 2) Furnace - 20 " "
- 3) Basement + Patio Lights - 20 amp Circuit
- 4) Living Room outlets - 20 amp Circuit
- 5) Garage outlets + Bathroom - 20 amp GFI
- 6) Master Bedroom + Dining Room outlets - 20 amp Circuit
- 7) Dining, Closet, Porch Lites - 20 amp Circuit
- 8) Master Bedroom Lites - 20 amp Circuit
- 9) Other Bed room (Lites + outlets) = 20 amp.
- 10) Garage Lites - 20 amp Circuit
- 11) Kitchen outlets + Lights - 20 amp. Circuit
- 12) Dryer - 30 amp Circuit
- 13) Refrigerator - 20 amp Circuit

