

209

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 810 Date April 30, 1984
 Job Location 1159 Woodlawn Valuation \$ 300.00
 Owner John L. Holden Address 1159 Woodlawn
Name Address
 Contractor _____ Telephone No. _____
 Address 1159 Woodlawn, Napoleon, Ohio 43545
 Electric Contractor _____
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential X Commercial _____ Industrial _____
No. dwelling units
 New Construction _____ Addition _____ Remodel _____
 Brief Description of Work _____

ISSUED BY Richard G. Hayman DEPT. OF BUILDING & ZONING
Building Official

PAID
 MAY 29 1984

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES OF NAPOLEON

Building Permit	\$ 7.00
Electrical Permit	\$ <u>21.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ 7.00 <u>21.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ 7.00 <u>21.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

THE NATIONAL SECURITY AGENCY - DEPT. OF DEFENSE
INFORMATION REPORT ON THE ACTS OF THE

010



[Faint, mostly illegible text covering the upper and middle sections of the page, possibly containing a report or memorandum.]



010

[Faint, mostly illegible text covering the lower left section of the page, possibly containing a list or table.]

[Faint, mostly illegible text covering the lower right section of the page, possibly containing a list or table.]



CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name John L. Holder Address 1159 Woodlawn

Electrical Contractor SELF Telephone No. 592-2596

Address _____

General Contractor _____ Telephone No. _____

Address _____

Location of Project 1159 Woodlawn Cost of Project 300.⁰⁰/₁₀₀

Work Information:

Residential ONE Commercial _____ Industrial _____
No. Units

New Service Change _____ Rewiring Additional Wiring _____

Brief Description of Work: _____

Size of proposed service entrance _____ Number of new circuits 16

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 4-27-84

Applicant's Signature John L. Holder

PERMIT NO. 810
PERMIT FEE \$ 24.00

PERMIT
CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. _____ Date April 30, 1984
 Job Location 1159 Woodlawn Valuation \$ 300.00
 Owner John L. Holden Address 1159 Woodlawn
 Contractor _____ Telephone No. _____
 Address 1159 Woodlawn, Napoleon, Ohio 43545
 Electric Contractor _____
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential X No. dwelling units Commercial _____ Industrial _____
 New Construction _____ Addition _____ Remodel _____
 Brief Description of Work _____

ISSUED BY _____ Building Official DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES


Building Permit	\$ <u>7.00</u>
Electrical Permit	\$ <u>21.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
TOTAL FEES	\$ <u>7.00 + 21.00</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>7.00 + 21.00</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND			ROUGH-IN &			FINAL		
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent		
	Building Sewer		Water Piping			Water Heater		
	Water Piping		Condensate Lines			Backflow Prevention		
			Indirect Waste					
ELECTRICAL	Floor Ducts Raceways		Rough Wiring			FINAL APPROVAL		
	Conduits & or Cable		Conduits/ Cable			Electric Mtr. Clearance		
	Grounding & or Bonding		Service Panel			Signs		
			Switchboard					
MECHANICAL	Refrigerant Piping		Subpanels					
	Ducts/ Plenums		<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL		10/1/84
			Refrigerant Piping			Duct Insulation		
			Ducts/ Plenums			Chimney(s)		
BUILDING			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			Furnace(s)		
	Location, Set-backs, Esmt(s)		Wall Construction			FINAL APPROVAL		
	Excavation		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Fireplace Chimney		
	Footings & Reinforcing		Floor System(s)			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access		
		Sub-soil Drain	Roof System			Special Insp Reports Rec'd		
Foundation Walls		Fire Wall(s)	Roof System			Smoke Detector		
Floor Slab		Roof Cover Roof Drain	Roof Drain			Demolition (sewer cap)		
FINAL APPROVAL BLDG. DEPT			Certificate of Occupancy Issued			#		

- GFI FOR BOTH
- 0 GARAGE RECP'TS
- (1) 20 A FOR REFRIG.
- (1) 20 A FOR MICRO.



EXIST-
ING
METER
BOX

10' PIECE 2" CONDUIT
#2 WIRE

THROUGH ROOF

APPROX. 16' ABOVE GROUND

14'-6"

5'-10"

5'

GARAGE

CITY OF NAPOLEON WORK ORDER

Nº 59937 ✓

Dept. Electric

Name John Holden

Date Ordered 10-8-84

Address 1159 Woodlawn

By Richard Heyman

LOCATION	Remove			Install		
	No.	Date	Rdg.	No.	Date	Rdg.
Electric						
Water						
Water Hr.						

Request: New service at 3:30 today if possible

Date Completed By

