



City of NAPOLEON

ENGINEERING DEPARTMENT

255 W. Riverview Avenue, PO Box 151, Napoleon, OH 43545
Phone: 419-592-4010 - Fax: 419-599-8393

Mayor
J. Andrew Small

Members of Council
Glenn A. Miller
President

Terri A. Williams
Ronald Behm
Travis B. Sheaffer
John A. Helberg
Steven C. Small
Michael J. DeWit

City Manager
Dr. Jon A. Bisher

Finance Director
Gregory J. Heath

Law Director
David M. Grahm

City Engineer
Chad E. Lulfs, P.E., P.S.

May 9, 2006

R-386 County Road 15
Napoleon, Ohio 43545

Attn: Joseph Lewis

Re: 1220 Woodlawn Avenue
Sewer Separation Notice

Dear Mr. Lewis,

It has come to our attention that you are currently rehabilitating/reconstructing the sanitary sewer service line on this property and that the service line is combined with the service line for 1214 Woodlawn Avenue. As per Rule 10.1 (E) in the City of Napoleon's Water & Sewer Rules:

A separate and independent building sewer shall be provided for every building; except where one (1) building stands at the rear of another on an interior lot and no private sewer is available or can be constructed to the rear building through an adjoining alley, court, yard, or driveway, the front building may be extended to the rear building and the whole considered as one (1) building sewer, but the City shall not be liable for damage caused by or resulting from any such single connection aforementioned.

This letter shall serve as notice that you have ninety (90) days to correct this situation from the date listed above. If corrective actions are not taken by such time, water service to the residence may be terminated. Please contact our office for all appropriate permits and to schedule inspections. If you have any questions or require additional information, please contact me at your convenience.

Yours truly,

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

COPY

cc: Jon A. Bisher, City Manager
Tom Zimmerman, Building & Zoning Inspector
Rex Moll, Construction Inspector

CEL/als