

SEWER TAPPING PERMIT

Issued by

The City of Napoleon Engineering Dept.

255 West Riverview Ave. Napoleon, Ohio 43545 Pn. 592-4010

Entry No. \_\_\_\_\_

Permit No. S.A.0097-89 Issued 4-14-89 Build. Permit No. N.A.

110.00  
 Permit Fee \$ 60.00

Job Location 1325 Woodlawn Ave.

Street Bond \$ \_\_\_\_\_

Lot \_\_\_\_\_ sub div. or legal disc.

Date Paid 4-18-89 60.00

Issued By FL

DALLAWCK DUB 50.00

Owner R J MAWAHAN Pn. 592-0976

TOTAL \$110.00

Address Co. Rd. M-1

Agent Standard Plumbing Pn. 592-5906

Address 1530 South St.

for office use only  
.....

WORK INFORMATION

Sanitary Sewer Tap  Size of Tap 4" Size and Type of Sewer SDR.35 P.V.C. Street to be Opened

Storm Sewer Tap \_\_\_\_\_ Size of Tap \_\_\_\_\_ Size and Type of Sewer \_\_\_\_\_ Street to be Opened

Street opening Agreement Approval Date \_\_\_\_\_ Opening Bond Fee (Set by Engineer) \_\_\_\_\_

READ AND SIGN BELOW; The undersigned hereby agrees complete the work described above and to make use of said sewers only as allowed by and in strict accordance with all applicable provisions of The Napoleon Engineering Dept. Rules and Regulations, The Napoleon Standard Specification for Water Main, Sanitary Sewer and Storm Sewer Construction and other Pertinent Sections of the Napoleon Code of Ordinances.

Date 4-14-89 Signature of Applicant Harold Delvaeth  
Permit not valid without signature

INSPECTION RECORD

to be completed by the Field Inspector

Date Inspection is made 4-14-89 Size and Type of Sewer 4" SDR.35 ASYM 3039

Location SEE PLAN Depth SEE PLAN Type of Test NONE Additional Information ALSO SEE

ATTACHED FIELD NOTES

Date \_\_\_\_\_ Inspected By \_\_\_\_\_ signature of inspector

Sketch Of Installation on Back or Attached

PD 4-14-89 - 60.00  
BAL. DUB 50.00  
TOTAL FEE 110.00

PAID

APR 14 1989

CITY OF NAPOLEON

Sewer inspection for Rao Bhatraju MD.

Woodlawn Ave, Address # 1325 Woodlawn

Contractor Jerry Glazzy

Date 14 Apr 89 by LOF

Replaced broken, poorly connected vit Clay 4" with  
new 4" PVC Sewer pipe

4" PSM-SDR 35 PVC Sewer D 3034  12454B  
819022CR

(A) = 14' to Furnco 5.5' Cover

(B) = 15.5' to Vertical 4" Riser ~~to~~ 5.5' Cover

(C) = ~~17.5~~ 17.5 Connection

(D) = 30.5 Furnco

(E) = 31' Cleanout

(F) = 32' Connection

(G) = 10.4' from East end along the build

(H) = 4' out from Building at  
4" PVC Clean out will be placed

Soil pipe 1' to FL

New 4" PVC 2' to FL

Existing

