

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 10-19-79

Permit No.

Type of Inspection Rough-in

Type of Occupancy

Project Name House

Address 1544 Woodlawn Ave

City Napoleon State OH

Approved

Violation

Electrical Contractor

Remarks:

Code Reference

Rough-in -

1) NM Cable supports within 8" of termination with loops having no clamps.

within 12" of termination with loops with clamps.

and always at least on 4 1/2 ft centers.

2) Lighting fixtures to be supported from outlet box having 2/32 MS.

Compliance Time

Inspectors Signature [Signature]

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector