

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01699 Issued 3-10-89
date

Job Location 917 Woodlawn
address

Lot PT-6 Lombard Add.
sub-div or legal discript

Issued By Eldon Huber
building official

Owner Carol Lugibihl
name tel.

Address 917 Woodlawn

Agent Stollsteimer Elec. 782-2673
builder-eng.-etc. tel.

Address 1478 S. Clinton - Defiance, OH

Description of Use Residence

Residential 1
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel X

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 500.00

ZONING INFORMATION N.A.

district	lot dimensions	area	front yd	side yds	rear yd
C					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: N.A.

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: 100 amp O.H. service & 20 circuits to replace existing.
brief description

Plumbing: N.A.
brief description

Mechanical: N.A.
brief description

Sign: N.A. Dimensions _____ Sign Area _____
type

Additional Information: _____

Date March 10, 89 Applicant Signature David D. Stollsteimer owner-agent

PAID
MAR 10 1989

CITY OF NAPOLEON

FEES	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	15.00	60.00	75.00
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			75.00
LESS MIN. FEES PAID			
BALANCE DUE.....			

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
			Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					

FIELD CORRECTION NOTICE

LOCATION 917 WOODLAWN PERMIT NO. 01699


ISSUED TO CAROL LOGGINSKI
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO CAROL LOGGINSKI

Upon inspection, violations of the _____ Sec. _____ were in evidence.

The following orders are hereby issued for their correction: _____

INCREASE THE WIDTH OF THE STAIR STEP
TREADS TO A MIN. OF 9"



PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE A. S. A. P.

DATE 9-21-89

BY ELDON HOBER
INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY

FIELD CORRECTION NOTICE

LOCATION 917 WOODLAWN PERMIT NO. 01699


ISSUED TO CAROL COBBIN
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO CAROL COBBIN

Upon inspection, violations of the _____ Sec. _____ were in evidence.

The following orders are hereby issued for their correction: _____

INCREASE THE WIDTH OF THE STAIR STEP
TREADS TO A MIN. OF 9"



PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE A. M. P.

DATE 7-21-89

BY ELDON HODER
INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

01689 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. Issued 3-10-89
date

Job Location 917 WOODLAWN
address

Lot 10M X 40 ADD
sub-div or legal descripr

Issued By 54
building official

Owner CAROL CUBIATILC
name tel

Address 917 WOODLAWN

Agent STOLLSTEINER ELDG. 782-2473
builder-eng-etc tel

Address 1478 S. CLINTON ST. DEF. OH.

Description of Use RESIDENCA

Residential 1
no dwelling units

Commercial Industrial

New Add'n. Alter Remodel X

Mixed Occupancy

Change of Occupancy

Estimated Cost \$ 500.00

FEEs	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	15.00	60.00	75.00
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. <u> </u> hrs		
	Elect. <u> </u> hrs		
TOTAL FEES.....			75.00
LESS MIN. FEES PAID <u> </u>			
	<small>date</small>		
BALANCE DUE.....			

ZONING INFORMATION NA

district	lot dimensions	area	front yd	side yds	rear yd
<u>C</u>					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: NA

Size: Length Width Stories Ground Floor Area

Height Building Volume (for demo. permit) cu. ft.

Electrical: 100 AMP O.H. SERV. & 20 CIR. TO REPLACE EXIST.
brief description

Plumbing: NA
brief description

Mechanical: NA
brief description

Sign: NA Dimensions Sign Area
type

Additional Information:

Date Applicant Signature owner-agent

APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name CAROL LUGIBIHL Address 917 WOODLAWN ST

Electrical Contractor STOLLSTEIMER ELECTRIC Telephone No. 782-2623

Address 1478 S. CLINTON ST DEFIANCE OHIO

General Contractor SAME Telephone No. SAME

Address SAME

Location of Project 917 WoodLawn Cost of Project \$500⁰⁰

Work Information:

Residential 1 Commercial 0 Industrial 0

No. Units

New Service Change X Rewiring Additional Wiring NONE

Brief Description of Work: INSTALL NEW SERVICE ENTRANCE 100A

Size of proposed service entrance 100A Number of new circuits 20

Type of proposed service entrance Underground Overhead X

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only sq. ft.

Additional Information:

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 25 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

date March 10, 89

Applicant's Signature David D. Stollsteimer

PERMIT NO.
PERMIT FEE \$

