

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 848-77 Issued 10-25-77
date

Job Location 937 Woodlawn Ave
address

~~XXX~~ SW 1/4 Sec. 13
sub-div or legal discript

Issued By Ronald D. Sonnenberg
building official

Owner I. A. Rodriguez 592-1349
name tel.

Address 937 Woodlawn

Agent G. A. Russell 274-4736
builder-eng.-etc. tel.

Address RR#1 Box 61 Hamler

Description of Use Service change.

Residential XX 1
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel XX

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 1,600.00

FEES	BASE	PLUS	TOTAL
BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$3.00	-0-	\$3.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$3.00
LESS MIN. FEES PAID _____			-0-
			<small>date</small>
BALANCE DUE.....			\$3.00

ZONING INFORMATION

district	lot dimensions <small>n/a</small>	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: n/a
brief description

Plumbing: n/a
brief description

Mechanical: n/a
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: SEE ATTACHED ADDENDUM:

Date Oct 26 1977 Applicant Signature Harry A. Russell Sr.
owner-agent

GARY RUSSELL

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

848-77

\$3.00

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name I. A. RODRIGUEZ Address 937 Woodlawn Ave 592-1349

Contractor's Name G. A. Russell Sr Address RR#1 Box 61 Tel. 274-4736

LOT INFORMATION:

Location of Project 937 Woodlawn Ave Zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing Addition _____

Replacement Remodel _____ Service Change

Size: Total Square Foot Per Floor 768 No. of Stories 2

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only _____ (Yes or No)

Total Number of New Circuits 5 Total Number of New Circuits Excluding Appliance Circuits _____

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric _____ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$1600.00

DATE Oct 25, 1977 APPLICANT'S SIGNATURE Gary A Russell Sr.
OWNER-CONTRACTOR-AGENT

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON, Building Dept.
 255 West Riverview Avenue
 Napoleon, Ohio 43545
 (419) 592-4010

ADDENDUM to Permit No. 848-77
Owner J.A. RODRIGUEZ
Location 937 Woodlawn

Please note the Items checked below and incorporate them into your plans as indicated: Permit not yet issued Correct Plans and Re-Submit. Permit Issued Incorporate the Items during construction.

GENERAL	
Provide 1 approved smoke detector.	Show size of members supporting porch roof.
Provide 1 hour fire wall and/or ceiling between garage and dwelling.	Provide double top plate.
Provide (Class B) 1 hour fire rated door from garage to dwelling.	Provide design data for pre-fab. wood truss/members.
Submit fully dimensioned plot plan.	Ceiling joists undersized in.....
Provide 1-3'0" x 6'8" exit door.
Provide min. 22" x 30" attic access.	Roof rafters undersized in.....
Provide min. 18" x 24" crawl space access opening.
LIGHT AND VENTILATION:	PLUMBING AND MECHANICAL:
Provide mechanical exhaust or window in bathroom.....	Terminate all exhaust systems to outside air.
Provide Min. _____ sq. in. net free area attic ventilation.	Insulate ducts in unheated areas.
Provide min. _____ sq. in. net free area crawl space ventilation.	Provide back flow device on all hose bibs.
FOUNDATION:	ELECTRICAL:
Min. depth of foundation below finished grade 30".	Show location of service entrance and service equipment panel.
Min. size of footer....." x"	G.F.C.I. req'd. on Temp. Electric.
Provide anchor bolts 1/2" @ 8' o.c. 1' from each corner. Embedded 8" concrete and 15" in masonry.	<input checked="" type="checkbox"/> Outdoor and bathroom receptacles shall be protected by G.F.C.I.
Show size of basement columns.	METAL VENEERS:
FRAMING:	Contact City Utilities Dept. to remove conductors and/or meter.
Show size of wood girder in.....	Provide 18" x 18" x 3/4" wood backer for meter base.
.....	Provide approved system of grounding and bonding.
Provide design data for structural member in.....	MISCELLANEOUS:
.....	Provide backwater valve in sub-soil drain tile.
Floor joists under sized in.....	Provide approved sheathing and flashing behind masonry veneer.
.....	Provide 15# felt underlayment on roof.
Provide double joists under parallel partitions.	Provide adequate fireplace hearth extensions
Provide 1" x 4" let in corner bracing or approved sheathing.	Install factory built fireplaces/stoves according to manufacturers recommendations.
Show size of headers for openings over 4' wide.	Terminate chimney 3' above roof or 2' above highest point of building within 10' of chimney.

ADDITIONAL CORRECTIONS: WORK SHALL CONFORM TO THE N.E.C., 1975 EDITION

The approval of plans and specifications does not permit the violation of any section of the Building Code, or other City Ordinance or State Law. This addendum is attached to Permit No. 848-77 and made a part thereof.

Date Approved or Disapproved 10-25-77

Checked By Ronald D. Jornerberg
Plan Examiner

Date Rechecked and Approved _____

Checked By _____

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name L.A. RODRIGUEZ

Address 997 WOODLAWN

City NAP State OH

Approved

Violation

Electrical Contractor RUSSELL

Remarks:

Code Reference

(1) GROUND FAULT REPT. IN BOTH BUS BARS 210-8 NEC

NOT FUNCTION ON TRIP TEST 1-5-78

(2) ALL NM CABLE SPLICES, JOINTS ETC 300-15 NEC

TO BE IN JUNCTION BOX LOW VOLT

TRANS. IN BASEMENT

(3) PROVIDE PROTECTION FOR NM 331-6 A+B

CABLE EXPOSED BELOW 2 FEET. NEC

BASEMENT

CORRECTIONS MADE 1-5-78

CALL FOR INSPECTION WHEN CORRECTIONS

HAVE BEEN MADE.

Compliance Time AT ONCE Inspectors Signature N. Howes

Copies To: G.A. RUSSELL RT 2 BOX 61 HAMLER, OHIO

