

**CITY OF NAPOLEON**  
**BUILDING CONSTRUCTION PERMIT**  
 (1, 2 or 3 Family Dwelling)

Permit No. 522-76  
 Issued 5/26/76  
 By Thomas W. Brown  
 Building Inspector

Valuation \$150.00

Fees	Base	Plus	Total
Construction	--	--	--
Plumbing	--	--	--
Electrical	\$3.00	--	\$3.00
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
<b>TOTAL</b>	<b>\$3.00</b>	<b>--</b>	<b>\$3.00</b>

Owner Name Mrs. Ed. Dargatzis  
 Address 902 West Main Street  
 Builder Name Jim Spalgar Electric  
 Address Napoleon, O. Tel. - 116

**Lot Information:**  
 Street No. 943 Woodlawn Ave.  
 Lot \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Lot Dimensions \_\_\_\_\_ Lot Area \_\_\_\_\_ Sq. Ft. \_\_\_\_\_  
 Yard Set Back: Front \_\_\_\_\_ Rear \_\_\_\_\_  
 Side \_\_\_\_\_ Side \_\_\_\_\_

Zoning R-1 Intended use of Building: Installing within 3' of the existing a 100AMP over-head electric service drop with the service equipment located below the water base.

**Building Information:**  
 Single  Double \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel   
 Size: Length \_\_\_\_\_ Width \_\_\_\_\_ No. of Stories \_\_\_\_\_  
 Floor Area: 1st Floor \_\_\_\_\_ 2nd Floor \_\_\_\_\_ 3rd Floor \_\_\_\_\_ Basement \_\_\_\_\_  
 Unfinished Attic \_\_\_\_\_ Garage \_\_\_\_\_  
 Foundation: Piers \_\_\_\_\_ Full Basement \_\_\_\_\_ Part Basement \_\_\_\_\_  
 Concrete \_\_\_\_\_ Block \_\_\_\_\_  
 Walls: Frame \_\_\_\_\_ Block \_\_\_\_\_ Brick \_\_\_\_\_ Other \_\_\_\_\_  
 Electrical: Wiring 100AMP \_\_\_\_\_ Electric Heating \_\_\_\_\_ Electrical Appliances \_\_\_\_\_  
 Plumbing: Fixtures or Traps \_\_\_\_\_ Warm Air Heating \_\_\_\_\_ Hot Water Heating \_\_\_\_\_

Additional Information: \_\_\_\_\_  
 Date 5-28-76 Applicant Signature [Signature]  
 Owner - Builder - Agent

**Inspection Record:**

Work Started	_____ Foundations	_____ Plumbing, Heating
Set Back, Side Lines	_____ Plumbing (Rough In)	_____ And Air Conditioning
Excavation	_____ Erecting Frame	_____ Roof
Roofing	_____ Electrical Work	

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 Certificate of Occupancy Issued \_\_\_\_\_  
 \_\_\_\_\_  
 Pink - Engineer Inspector

Date: 5-25-76

TO: Electric Distribution Superintendent

FROM: The Building Inspector - Engineering Dept.

Please confirm the installation of 100 AMP, electrical service entrance, located SAME LOCATION OF EXISTING. (OVER-HEAD SERVICE.)

at the following address: 943 WOODLAWN AVE,

Approved  Not Approved

REHARRIS  
Electric Supt.

5-25-76  
Date

Remarks:

CITY OF NAPOLEON  
ENGINEERING DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)

RECEIVED,

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Mrs. Ed Desgrange Address 902 West Main Street

Contractor's Name Jim Speiser Electric Address Napoleon, Ohio Tel. 599-1846

LOC INFORMATION:

Location of Project 943 Woodlawn Avenue Zoning District

BUILDING INFORMATION:

Single Family  Double Family  Multiple Family

New Construction  Existing  Addition

Replacement  Remodel  Service Change

Size: Total Square Foot Per Floor  No. of Stories

DESCRIPTION OF WORK:

Size of Service 100 AMP. Service Change Only  (Yes)

Total Number of New Circuits 0 Total Number of New Circuits Excluding Appliance Circuits 0

APPLIANCE CIRCUITS: (Indicate quantity)

Electric Range  Range Hood  Clothes Dryer  Dishwasher

Air Conditioner  Attic Fan Blower  Room Exhaust Fan

Disposal  Hot Water Heater  Electric Oven

Require Temporary Electric  (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$150.00

DATE 5/25/1976 APPLICANT'S SIGNATURE James Speiser  
OWNER-CONTRACTOR-AGENT

\$3.00

**JIM SPEISER ELECTRIC**  
R. R. 2 BOX 201  
PH. 599-1846 NAPOLEON, OHIO 43545




POWER COMPANY SERVICE

3-#2 THW IN 1/4" CONDUIT



100A. METER SOCKET.

3-#2 THW IN 1/4" CONDUIT



SERVICE EQUIPMENT  
100A. MAIN 120/230V 1Ø 3 WIRE  
SIN WITH 24 BRANCH Ckt.  
TOTAL OF 26 CIRCUITS

#6 COPPER GROUND



**JIM SPEISER ELECTRIC**  
R. R. 2 BOX 201  
PH. 599-1846 NAPOLEON, OHIO 43545

A 1% Service Charge per month will be added to unpaid balances with all bills. Minimum charge of \$1.00.