

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: ST. RT. 110 Low service Pump Station Zip: 43545
 Business Name: Campbell's Soup
 Contact Person: David Bartley Title: Senior Operator
 Phone Number: 592-1010 EXT. 207 Date of Test: 7-23-99

DEVICE INFORMATION

Type (circle one) **RP** DC VB RPDA DCDA
 Manf/Model: Watts 009 m2 QT Size: 1" Serial No.: 52378
 Location of Device: 2nd level S.W. corner
 Type of Test: Differential Gauge Sight Tube

| Outlet Valve Holding <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | Reduced Pressure Assembly | | Pressure Vacuum Breaker | | |
|---|--|---|---|---|--|
| | Double Check Valve | | Relief Valve | Air Inlet | Check Valve |
| | 1st Check | 2nd Check | | | |
| Test Results <u>Pass</u> | DC _____ psi <u>Apparent</u> RP <u>8.6</u> psi <u>Actual</u> RP <u>8.0</u> psi | DC _____ psi | Opened at <u>2.6</u> psi Did Not Open <input type="checkbox"/> | Opened at _____ psi Did Not Open <input type="checkbox"/> | Held at _____ psi Leaked <input type="checkbox"/> |
| Date: <u>7-23-99</u> | Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> |
| Repairs & Materials | | | | | |
| Test After Repairs | DC _____ psi RP _____ psi | DC _____ psi RP _____ psi | Opened At _____ psi Did Not Open <input type="checkbox"/> | Opened At _____ psi Did Not Open <input type="checkbox"/> | Held At _____ psi Leaked <input type="checkbox"/> |
| Date: | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> |

Tester Signature: David B. Brown Certification No. 528
 Owner/Representative Signature: David Bartley CSC