City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Type (circle Manf/Model: Location of I Type of Test	: Watts &	DC 069 M2 Q7	Size: 13	RPDA Serial No	18595
Outlet	Reduced Pre	ssure		Pressure Vacuum Breaker	
valve	Assembly		1		
holding RP DC□	Double Check Valve		Relief Valve	Air Inlet	Check Valve
failed RP□ DC□	1st Check	2nd Check	₩.		
Test Results	DCpsi	DCpsi	opened at 4.1 psi	opened atpsi	held at
Pa55	RP <u>8.25</u> psi		did not	did not	leaked
Date: 9-4-02	Pass 🕸	Pass Ž	open Pass	open Pass	Pass
	Failed	Failed	Failed	Failed	Failed
Repairs & Materials					
Test After	DC psi	DC psi	opened at	opened at	held at
Repairs	RPpsi	RPpsi	did not open	did not open	leaked
Date:	Pass □ Failed □	Pass 🔟	Pass Failed	Pass Failed	Pass □ Failed □