

P E R M I T

CITY OF NAPOLEON
255 W. RIVERVIEW AVE
NAPOLEON, OHIO 43545

DIVISION OF BUILDING & ZONING
PH (419) 592-4010
FAX (419) 599-8393

PERMIT NO: 1486 DATE ISSUED: 01-13-03 ISSUED BY: BND

JOB LOCATION: 0368 ST RT 108 EST. COST:

LOT #: SUBDIVISION NAME:

OWNER: SHEPARD, BECKY AGENT: SELF
ADDRESS: 0368 SR 108 ADDRESS:
CSZ: NAPOLEON, OH 43545 CSZ:
PHONE: 419-592-2026 PHONE:

USE TYPE - RESIDENTIAL: OTHER:

ZONING INFORMATION

DIST: LOT DIM: AREA: FYRD: SYRD: RYRD:
MAX HT: # PKG SPACES: # LOADING SP: MAX LOT COV:

BOARD OF ZONING APPEALS:

WORK TYPE - NEW: REPLMNT: ADD'N: ALTER: REMODEL:

WORK INFORMATION

SIZE - LGTH: WIDTH: STORIES: LIVING AREA SF:
GARAGE AREA SF: HEIGHT: BLDG VOL DEMO PERMIT:

WORK DESCRIPTION
ELEC SERV UPGRADE
200 OH

FEE DESCRIPTION	PAID DATE	FEE AMOUNT DUE
ELECTRICAL PERMIT		0.00

TOTAL FEES DUE 0.00

DATE

APPLICANT SIGNATURE

CITY OF NAPOLEON

ELECTRIC METER BASE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" ELECTRIC METER BASE
(Please pickup at the City operations garage 1775 Industrial Drive).

PERMIT #: 1486

ISSUED: 01-13-2003

JOB LOCATION: 0368 ST RT 108

WORK DESCRIPTION: ELEC SERV UPGRADE

OWNER: SHEPARD, BECKY

ADDRESS: 0368 SR 108 NAPOLEON, OH 43545

OWNER PHONE: 419-592-2026

CONTRACTOR: SELF

ADDRESS:

CONTRACTOR PHONE:

ELECTRIC SERVICE UPGRADE NEW SERVICE INSTALLATION _____

INDUSTRIAL _____ COMMERCIAL _____ RESIDENTIAL 1PHASE _____ 3PHASE _____

SIZE OF SERVICE 100AMP _____ 150AMP _____ 200AMP 400AMP _____ OTHER _____

HUB SIZE - 1 1/4" _____ 1 1/2" _____ 2" _____

DESIRED VOLTAGE 120/240 OTHER _____

UNDERGROUND SERVICE _____ OVERHEAD SERVICE

=====

DATE COMPLETED: _____ APPROVED BY: _____

OLD METER NUMBER: _____ NEW METER NUMBER: _____

COMMENTS:

wed 5:15

SERVICE CHANGE - FOR REBECCA SHEPARD

LOCATION

592-2026-H

2-6764 Todd



592-1024-B

O-368 SR 108 - 1st HOUSE ON EAST SIDE, SOUTH OF MAPLEDALE,
OUTSIDE C.M. LIMIT - BY CATHOLIC CHURCH

UPGRADE FROM 100 AMP TO 200 AMP SERVICE

DRAWING OF EXISTING

PROPOSED SERVICE CHANGE



ELIMINATE 2 - 100 AMP METERS
DRIP LINE AT 8'6" PRESENTLY

INSTALL 1 - 200 AMP SERVICE
BRING UP TO CODE -
DRIP LINE TO MINIMUM 12'
MAST TO GO 3' ABOVE ROOF TO ACCOMMODATE

RICK BARNES INSPECTED SITE (592 9116) MONDAY JAN 6TH 2 PM.

TOLD US - ① CITY NEEDS DRAWING OF PROPOSAL

- ② GET PERMIT - METER BASE FROM CITY NOTIFY
- ③ AT LEAST 2 DAYS NOTICE FOR SERVICE CHANGE FOR CITY TO SCHEDULE