

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01693 Issued 2-1-89 date
 Job Location 203 Brownell address
 Lot 26 Springwells Addition sub-div or legal discript
 Issued By Eldon Huber building official
 Owner Ed Hoffman name tel.
 Address 203 Brownell
 Agent Damman Electric builder-eng.-etc. tel.
 Address R.R. 1 - Napoleon, Ohio 43545
 Description of Use Residence
 Residential 1 no. dwelling units
 Commercial _____ Industrial _____
 New _____ Add'n. _____ Alter _____ Remodel X
 Mixed Occupancy _____
 Change of Occupancy _____
 Estimated Cost \$ 400.00

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	15.00	3.00	18.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			18.00
LESS MIN. FEES PAID _____ date			
BALANCE DUE.....			

ZONING INFORMATION N.A.

district	lot dimensions	area	front yd	side yds	rear yd
A					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: N.A.

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
 Height _____ Building Volume (for demo. permit) _____ cu. ft.
 Electrical: Replace existing with new 200 amp O.H. service. brief description
 Plumbing: N.A. brief description
 Mechanical: N.A. brief description
 Sign: N.A. Dimensions _____ Sign Area _____
 Additional Information: _____

Date 2-1-89 Applicant Signature *Al Damman* owner-agent
 FEB 01 1989
 CITY OF NAPOLEON

INSPECTION RECORD

UNDERGROUND			ROUGH-IN						FINAL		
Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains		Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping								Backflow Prevention		
	Building Sewer		Water Piping			Condensate Lines			Water Heater		
	Sewer Connection								FINAL APPROVAL		
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s)			Grease Exhaust System		
			Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums		Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
			Duct Insulation			Pool Heater			Furnace(s)		
			Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable		Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)		Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation					Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing					<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab		Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls		Columns & Supports			Fireplace Chimney					
	Sub-soil Drain		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles		Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
		Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.					INSPECTIONS, CORRECTIONS, ETC.					

FEB 01 1987
 10 837

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

01694 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. Issued 2-1-89
date

Job Location 203 BROWNELL
address

Lot 26 SPRINGWELLS ADD.
sub-div or legal descripr

Issued By 54
building official

Owner ED HOFFMAN
name tel

Address 203 BROWNELL

Agent DANNAN ELEC.
builder-eng-etc tel

Address PRI NAP, OHIO

Description of Use RESIDENCE

Residential 1
no dwelling units

Commercial Industrial

New Add'n. Alter Remodel X

Mixed Occupancy

Change of Occupancy

Estimated Cost \$ 700.00

FEE	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	15.00	3.00	18.00
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. <u> </u> hrs		
	Elect. <u> </u> hrs		
TOTAL FEES.....			18.00
LESS MIN. FEES PAID			
	<small>date</small>		
BALANCE DUE.....			

ZONING INFORMATION NA

district <u>A</u>	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: NA

Size: Length Width Stories Ground Floor Area

Height Building Volume (for demo. permit) cu. ft.

Electrical: REPLACE EXISTING WITH NEW 200 AMP O.H. SERVICE
brief description

Plumbing: NA
brief description

Mechanical: NA
brief description

Sign: NA Dimensions Sign Area
type

Additional Information:

Date Applicant Signature
owner-agent

APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Ed Hoffman Address 203 BROWNELL

Electrical Contractor Dammann Electric Telephone No. 598-8663

Address Route 1 Napoleon

General Contractor _____ Telephone No. _____

Address _____

Location of Project 203 BROWNELL Cost of Project 400.00

Work Information:

Residential 1 Commercial _____ Industrial _____
No. Units

New _____ Service Change Rewiring _____ Additional Wiring _____

Brief Description of Work: Change service to 200 Amp
Overhead

Size of proposed service entrance 200 Number of new circuits 0

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

PERMIT NO. 01693
PERMIT FEE \$ 18.00

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

date 2-1-89

Applicant's Signature Alan Dammann

PAID
FEB 01 1989
CITY OF NAPOLEON

METER SOCKET RELEASE

DATE 1 Feb 89

JOB ADDRESS 203 Brownell

PERMIT NO. 01693

OWNERS NAME Ed Hoffman

OWNERS ADDRESS 203 Brownell PHONE _____

CONTRACTOR Damman Electric

CONTRACTORS ADDRESS Route # 1 PHONE 598-8663

SIZE OF SERVICE 200 OVERHEAD UNDERGROUND _____

DATE APPROVED 1 Feb 89 APPROVED BY Roger O Fraytag

