

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Fred Best
 Address 1203 Detroit Avenue
 Builder Name Self
 Address Same Tel. 592-4215

Lot Information:
 Street No. 1203 Detroit Avenue
 Lot # 10 Subdivision Van Yencor's 1st Add.
 Lot Dimensions 66' x 120' Lot Area 7,854 Sq. Ft.
 Yard Set Back: Front NOT APPLICABLE Rear
 Side Side

Zoning "C" Intended use of Building: Remodel Existing Porch

Building Information:

Single X Double Multiple New Construction Addition Remodel X
 Size: Length 12' Width 6'-3" No. of Stories 1
 Floor Area: 1st Floor 80 sq' 2nd Floor 3rd Floor Basement
 Unfinished Attic Garage
 Foundation: Piers Full Basement Part Basement
 Concrete Feetor Block walls 8"
 Walls: Frame Block Brick Other
 Electrical: Wiring Electric Heating Electrical Appliances
 Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the attached addendum marked Exhibit "A" and made a part here-of.

Date 7-8 Applicant Signature Fred Best
 Owner - Builder - Agent

Inspection Record:

Work Started 7-7-76 Foundations Plumbing, Heating
 Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
 Excavation 7/1/76 Erecting Frame Roof
 Footing POURED 7/1/76 CK'D Electrical Work
Bx Aux., OK

Comments: Check & Approved 2/15/77 BBA

Certificate of Occupancy Issued Pink - Engineer
 Inspector

Permit No. 555-76
 Issued July 7, 1976
 By Fred Best Building Inspector
 Valuation \$125.00

Fees	Base	Plus	Total
Construction	<u>\$3.00</u>	<u>---</u>	<u>\$3.00</u>
Plumbing	<u> </u>	<u> </u>	<u> </u>
Electrical	<u> </u>	<u> </u>	<u> </u>
Heating	<u> </u>	<u> </u>	<u> </u>
Water Tap	<u> </u>	<u> </u>	<u> </u>
Sewer Tap	<u> </u>	<u> </u>	<u> </u>
Temporary Elec.	<u> </u>	<u> </u>	<u> </u>
TOTAL	<u>\$3.00</u>	<u>---</u>	<u>\$3.00</u>

555-76
592-4215

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name James Burt Address x/203 DeWitt ave

Builder's Name P. Riviere Address x Park St - Tel. x

LOT INFORMATION: (Not required for roofing or siding job.) 66 X 119'

Location of Project _____ Lot # 10

Subdivision Willenger 1st Add. Lot Area _____ Sq. Ft. _____

Yard Set Back: Front _____ Rear _____ Left Side _____

Right Side _____ Zoning District _____

BUILDING INFORMATION:

Single ↓ Double _____ Multiple _____ New Construction _____

Addition _____ Remodel _____ Attached Garage _____

Detached Garage _____ Accessory Building Porch, Replacement _____

Brief Description of Work: x

Size: Length 80" Width 144" No. of Stories _____

Floor Area: 1st Floor _____ Sq. Ft. 2nd Floor _____ Sq. Ft.

3rd Floor _____ Sq. Ft. Basement _____ Sq. Ft.

Unfinished Attic _____ Garage _____

x Foundation: Piers _____ Full Basement _____ Part Basement _____

Concrete 8" Thickness Block _____ Size _____

Walls: Frame _____ Block x Brick _____ Other _____

Specific Type of Exterior Siding _____

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: x \$12500

DATE x 7-7-76 . APPLICANT'S SIGNATURE x James Burt,
OWNER-BUILDER-AGENT

MEMO

1203

from ^{Tom}~~TOM~~ TERRANOVA

TO Tom DATE 7-7-76 TIME

SUBJECT Fred Bost WANTS INSPECTION ON FOOTERS FOR PORCH. I called him this morning at his request and informed him footers should be 30" deep. He thought they were deep enough the way they now had them, and wanted you to make an inspection. I informed him you were not in and I would have you go out at 1:00 o'clock when you returned.

R.T.S.

