

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT**

(1, 2 or 3 Family Dwelling)

Owner Name Robert Whinnery

Address 1213 Detroit Ave.

Builder Name Harold Bostelman Electrical Co.

Address 618 Park St. Tel. 592-2383

**Lot Information:**

Street No. 1213 Detroit Ave.

Lot 9 Subdivision W.N. Yeager 1st Add

Lot Dimensions --- Lot Area --- Sq. Ft.

Yard Set Back: Front --- Rear ---

Side --- Side ---

Zoning "C" Intended use of Building: installing on the south side of the existing dwelling a new 100AMP. over head electric service drop with the service equipment located in the basement, also re-wiring basement only.

**Building Information:**

Single  Double  Multiple  New Construction  Addition  Remodel

Size: Length --- Width --- No. of Stories 2

Floor Area: 1st Floor --- 2nd Floor --- 3rd Floor --- Basement ---

Unfinished Attic  Garage

Foundation: Piers  Full Basement  Part Basement

Concrete  Block

Walls: Frame  Block  Brick  Other

Electrical: Wiring 100AMP Electric Heating --- Electrical Appliances ---

Plumbing: Fixtures or Traps  Warm Air Heating  Hot Water Heating

Additional Information: ---

Date --- Applicant Signature Harold Bostelman

NOTE: 3/11/76 CONTRACTOR ALSO WIRING 1st AND 2nd FLOOR, INFORMED HIM SUBJECT TO FINAL INSPECTION WHEN COMPLETED. Paul, 7/17/76 FINAL ELECTRICAL INSPECTED APPROVED BY HOWES.

**Inspection Record:**

Work Started  Foundations  Plumbing, Heating

Set Back, Side Lines  Plumbing (Rough In)  And Air Conditioning

Excavation  Erecting Frame  Roof

Footing  Electrical Work 3/11/76 SERVICE, PANEL AND ROUGH-IN WIRING INSPECTED AND APPROVED BY HOWES.

Comments: 7/17/76 Romex FROM T.B. OVER FURNACE SHOULD BE COVERED WITH GREEN-FIELD FOR PROTECTION OF MECH. DAMAGE, BOSTELMAN INFORMED BY HOWES 7/17/76

Certificate of Occupancy Issued

Permit No. 458-76

Issued 3/12/76

By Paul W. Howes  
Building Inspector

Valuation \$600.00

Fees	Base	Plus	Total
Construction	---	---	---
Plumbing	---	---	---
Electrical	<u>\$3.00</u>	<u>\$1.75</u>	<u>\$4.75</u>
Heating	---	---	---
Water Tap	---	---	---
Sewer Tap	---	---	---
Temporary Elec.	---	---	---
<b>TOTAL</b>	<u>\$3.00</u>	<u>\$1.75</u>	<u>\$4.75</u>



CITY OF NAPOLEON  
ENGINEERING DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name ROBERT-WHINNERY Address 1213 DETROIT

Contractor's Name HAROLD BOSTELMAN Address 618 PARK Tel. 592-2383

LOT INFORMATION: W N. Yager Lot 9  
Location of Project 1213 DETROIT Zoning District \_\_\_\_\_

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple Family \_\_\_\_\_

New Construction \_\_\_\_\_ Existing \_\_\_\_\_ Addition \_\_\_\_\_

Replacement \_\_\_\_\_ Remodel add Couple Rec. + Rewire Basement Service Change

Size: Total Square Foot Per Floor \_\_\_\_\_ No. of Stories 2

16 Total

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only YES (Yes or No)

7 Existing Circuits  
Total Number of New Circuits 2 Total Number of New Circuits 2  
Excluding Appliance Circuits \_\_\_\_\_

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range  Range Hood \_\_\_\_\_ Clothes Dryer \_\_\_\_\_ Dishwasher \_\_\_\_\_

Air Conditioner \_\_\_\_\_ Attic Fan Blower \_\_\_\_\_ Room Exhaust Fan \_\_\_\_\_

Disposal \_\_\_\_\_ Hot Water Heater  Electric Oven \_\_\_\_\_

Require Temporary Electric NO (Yes or No)


Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: 600.00





DATE 2-9-76 APPLICANT'S SIGNATURE Harold Bostelman  
OWNER-CONTRACTOR-AGENT





MOVE NEW INTRANCE  
2 FT SOUTH FROM PRESENT INTRANCE.  
INTRANCE - WEST SIDE

1 1/4" Conduit  
3 # 2 T.H.W. Wire 120VOLT




100 AMP MAIN  
16 CIR.  
BREAKER  
PANEL  
IN BASEMENT

GROUND TO ROD + WATER LINE


ROBERT WHINNERY  
1213 - DETROIT



YEAGER ST.



gao  
 cwp  
 city  
 10/12/82  
 10/12/83  
 10/12  
 OK for Thursday  
 10-15-92



*Law*

**Napoleon Power & Light**

1775 Industrial Drive Napoleon, Ohio

ITEM 1213 & 1217 DETROIT ST.

DATE [ ] W.O.F. [ ] DATE [ ] DRAWN BY [ ]

