

# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01181 Issued 6-16-86  
date

Job Location 1415 Glenwood Avenue  
address

Lot 29 Harmony Acres  
sub-div or legal discript

Issued By Eldon Huber  
building official

Owner Gary Rebeau 599-2231  
name tel.

Address 1415 Glenwood Avenue

Agent Gary Rebeau 599-2231  
builder-eng.-etc. tel.

Address 1415 Glenwood Avenue

Description of Use Residence

---

Residential 1  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. X Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 12,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	24.00	27.00
<input checked="" type="checkbox"/> ELECTRICAL	5.00	8.00	13.00
<input checked="" type="checkbox"/> PLUMBING	3.00	3.00	6.00
<input checked="" type="checkbox"/> MECHANICAL	6.00	.00	6.00
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			.00
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs _____	Elect. _____ hrs _____	
TOTAL FEES.....			\$52.00
LESS MIN. FEES PAID _____			_____
BALANCE DUE.....			_____

### ZONING INFORMATION

district <b>A</b>	lot dimensions <b>100' X 120'</b>	area <b>12,000 S.F.</b>	front yd <b>30' Min.</b>	side yds <b>7' Min.</b>	rear yd <b>15' Min.</b>
max hgt <b>35' Max.</b>	no pkg spaces <b>2-Min.</b>	no ldg spaces <b>0</b>	max cover <b>35% Max.</b>	petition or appeal req'd	date appr

### WORK INFORMATION:

Size: Length 22' Width 35' Stories 1 Ground Floor Area 770 S.F.

Height 12' Aver. Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: Lighting outlets misc.  
brief description

Plumbing: New bathroom  
brief description

Mechanical: New furnace & ductwork  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: Smoke detectors required at bedroom area and at each story in existing building min. 40# live 10# dead load on floor joists. See attached correction sheet.

Date 6-16-86 Applicant Signature Gary J. Rebeau owner-agent

**PAID**  
 JUN 16 1986  
**CITY OF NAPOLEON**

# INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
<b>PLUMBING</b>	Building Drains			Drainage, Waste & Vent Piping	2/24	EH	Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
<b>MECHANICAL</b>	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
<b>ELECTRICAL</b>	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
<b>BUILDING</b>	Location, Set-backs, Esmt(s)	6-25 86	EH	Exterior Wall Construction	7/22	EH	Roof Covering Roof Drainage			Smoke Detector		
	Excavation	6-25 86	EH				Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing	6-25 86	EH				<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction	9/9	EH	Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System	7/22	EH	Special Insp Reports Rec'd			Certificate of Occupancy Issued		
<b>ADDITIONAL</b>	<b>INSPECTIONS, CORRECTIONS, ETC.</b>						<b>INSPECTIONS, CORRECTIONS, ETC.</b>					
	NOTE TO INSTALL LATERAL TRACING BTWN FLOOR JOISTS AREA						9/19 EH					
	824 WALL + HEADER						11/74 EH					
	DOWNSPOUTS 120											
	SEWER (TAKEN OUT)											



RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON  
255 West Riverview Ave.  
Napoleon, Ohio 43545  
419/592-4010

ADDENDUM TO Permit No. 01181  
Owner CARY BREHAD  
Contractor " "  
Location 1415 CLEAVELAND AVE.

Please note the items checked below and incorporate them into your plans as indicated: PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL		Show size of members supporting porch roof.	
<input type="checkbox"/>	Provide approved smoke detector(s) as req'd.	<input checked="" type="checkbox"/>	Provide double top plate for all bearing partitions and exterior walls.
<input type="checkbox"/>	Provide ½" gypsum wallboard between dwelling and garage, on garage side.	<input checked="" type="checkbox"/>	Provide design data for prefab wood truss.
<input type="checkbox"/>	Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		Ceiling joists undersized in _____
<input type="checkbox"/>	Submit fully dimensioned plot plan.		Roof rafters undersized in _____
<input type="checkbox"/>	Provide min. of 1-3'0" x 6'8" exit door.	PLUMBING AND MECHANICAL	
<input checked="" type="checkbox"/>	Provide min. 22" x 30" attic access opening.	<input checked="" type="checkbox"/>	Terminate all exhaust systems to outside air.
<input checked="" type="checkbox"/>	Provide min. 18" x 24" crawl space access opening.	<input checked="" type="checkbox"/>	Insulate ducts in unheated areas.
<input type="checkbox"/>	Provide approved sheathing or flashing behind masonry veneer.	<input checked="" type="checkbox"/>	Provide backflow prevention device on all hose bibs.
<input type="checkbox"/>	Provide min. 15# underlayment on roof.		Terminate pressure and temperature relief valve drain in an approved manner.
<input type="checkbox"/>	Provide adequate fireplace hearth.		Provide dishwasher drain with approved air gap device.
<input type="checkbox"/>	Install factory built fireplaces/stoves according to manufacturers instructions.	METAL VENEERS	
<input type="checkbox"/>	Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		Contact City Utilities Dept. to remove conductors and/or meter.
LIGHT AND VENTILATION			Provide approved system of grounding and bonding.
<input type="checkbox"/>	Provide mechanical exhaust or window in bathroom _____	ELECTRICAL	
<input type="checkbox"/>	Provide min. <u>739</u> Sq. In. net free area attic ventilation.		Show location of service entrance panel and service equipment panel.
<input checked="" type="checkbox"/>	Provide min. <u>165</u> Sq. In. net free area crawl space ventilation.		G. F. C. I. req'd. on temporary electric.
FOUNDATION			Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.
<input type="checkbox"/>	Min. depth of foundation below finished grade is 32".		Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.
<input type="checkbox"/>	Min. size of footer <u>6</u> " x <u>15</u> ".		Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.
<input checked="" type="checkbox"/>	Provide anchor bolts ½" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.	INSPECTIONS	
<input type="checkbox"/>	Show size of basement columns.		The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs prior to the time the inspection is to be made.
FRAMING		<input checked="" type="checkbox"/>	Footers and Setbacks.
<input checked="" type="checkbox"/>	Show size of wood girder <sup>OR BEAM 2-2X8S</sup> in <u>BASEMENT</u> .	<input checked="" type="checkbox"/>	Building sewer.
<input checked="" type="checkbox"/>	Provide design data for structural member in <u>ROOF TRUSS DIAGRAM</u>	<input checked="" type="checkbox"/>	Foundation.
<input type="checkbox"/>	Floor joists undersized in _____	<input checked="" type="checkbox"/>	HVAC rough-in.
<input type="checkbox"/>	Provide double joists under parallel bearing partitions.	<input checked="" type="checkbox"/>	Plumbing rough-in.
<input checked="" type="checkbox"/>	Provide 1" x 4" let in corner bracing, approved sheathing, or equal.	<input checked="" type="checkbox"/>	Final Building other,
<input checked="" type="checkbox"/>	Show size of headers for openings over 4' wide <u>2-2x12s</u> .	<input checked="" type="checkbox"/>	Plumbing final.
		<input checked="" type="checkbox"/>	Electrical service.
		<input checked="" type="checkbox"/>	Electrical rough-in.
		<input checked="" type="checkbox"/>	Electrical final

Additional Corrections. PROVIDE SMOKE DETECTORS IN THE EXISTING BUILDING AT SLEEPING AREAS AND AT LEAST 1-PER STORY ROOM 36" CLEAR TO TOP + 12" CLEAR TO FRONT, BACK + SIDES OF FIREPLACE

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01181 and made a part there-of. DATE APPROVED OR DISAPPROVED 6-10-86 Checked by EH Plan Examiner.  
DATE RECHECKED AND APPROVED 6-11-86 Checked by EH





# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01181 Issued 6-16-86 date

Job Location 1415 Glenwood Avenue address

Lot 29 Harmony Acres sub-div or legal discript

Issued By Eldon Huber building official

Owner Gary Rebeau name 599-2231 tel.

Address 1415 Glenwood Avenue

Agent Gary Rebeau builder-eng.-etc. 599-2231 tel.

Address 1415 Glenwood Avenue

Description of Use Residence

Residential 1 no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n.  Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 12,000.00

	FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING		3.00	24.00	27.00
<input checked="" type="checkbox"/> ELECTRICAL		5.00	8.00	13.00
<input checked="" type="checkbox"/> PLUMBING		3.00	3.00	6.00
<input checked="" type="checkbox"/> MECHANICAL		6.00	.00	6.00
<input type="checkbox"/> DEMOLITION				
<input checked="" type="checkbox"/> ZONING				.00
<input type="checkbox"/> SIGN				
WATER TAP				
SEWER TAP				
TEMP. ELECT.				
ADDITIONAL PLAN REVIEW	Struct. _____ hrs			
	Elect. _____ hrs			
TOTAL FEES.....				\$52.00
LESS MIN. FEES PAID _____ date				
BALANCE DUE.....				

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
A	100' X 120'	12,000 S.F.	30' Min.	7' Min.	15' Min.
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35' Max.	2-Min.	0	35% Max.		

### WORK INFORMATION:

Size: Length 22' Width 35' Stories 1 Ground Floor Area 770 S.F.

Height 12' Aver. Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: Lighting outlets misc. brief description \_\_\_\_\_

Plumbing: New bathroom brief description \_\_\_\_\_

Mechanical: New furnace & ductwork brief description \_\_\_\_\_

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: Smoke detectors required at bedroom area and at each story existing building min. 40# live 10# dead load on floor joists. See attached plan correction sheet.

Date 6-16-86 Applicant Signature Gary Rebeau owner-agent

**PAID**  
JUN 16 1986  
CITY OF NAPOLEON





# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01181 Issued 1/15 date

Job Location 1415 GLENWOOD AVE. address

Lot 29 HARMONY ACRES sub-div or legal discript

Issued By FH building official

Owner GARY REBEAU 599-2231 name tel.

Address 1415 GLENWOOD

Agent GARY REBEAU 599-2231 builder-eng.-etc. tel.

Address 1415 GLENWOOD

Description of Use RESIDENCE

Residential 1 no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. X Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 17000.00

	FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING		3.00	24.00	27.00
<input checked="" type="checkbox"/> ELECTRICAL		5.00	8.00	13.00
<input checked="" type="checkbox"/> PLUMBING		3.00	3.00	6.00
<input checked="" type="checkbox"/> MECHANICAL		6.00	1.00	6.00
<input type="checkbox"/> DEMOLITION				
<input checked="" type="checkbox"/> ZONING				1.00
<input type="checkbox"/> SIGN				
WATER TAP				
SEWER TAP				
TEMP. ELECT.				
ADDITIONAL PLAN REVIEW	Struct. _____ hrs			
	Elect. _____ hrs			
TOTAL FEES.....				
LESS MIN. FEES PAID _____ date				
BALANCE DUE.....				<u>52.00</u>

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
<u>A</u>	<u>100' x 120'</u>	<u>12000 S.F.</u>	<u>30' MIN.</u>	<u>7' MIN.</u>	<u>15' MIN.</u>
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
<u>35' MAX.</u>	<u>2-MIN.</u>	<u>0</u>	<u>35% MAX.</u>		

### WORK INFORMATION:

Size: Length 22' Width 35' Stories 1 Ground Floor Area 770 S.F.

Height 12' AVER. Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: LIGHTING OUTLETS MISCL brief description

Plumbing: NEW BATHROOM brief description

Mechanical: NEW FURNACE + DUCTWORK brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: SMOKE DETECTORS REQ. AT BEDROOM AREA AND AT EACH STORY IN EXISTING BUILDING MIN 10# LIVE 10# DEAD LONDON FLUORIST SEE ATTACHED PLAN CORRECTION SHEET.

Date \_\_\_\_\_ Applicant Signature \_\_\_\_\_ owner-agent





CALL 599-2231  
GARY REBEAU

TRUSS DIAGRAM

~~BASEMENT COLUMNS~~

X BEAMS

X HEADER SIZE

EXISTING ELEC. SERVICE EXISTING OR RELOCATED

8'-0" CEILING HT.

TYPE OF LUMBER FOR FLOOR JOISTS


S Y P



01181 GARY TREBEAU

LOT 29

HARMONY ACRES



LOCATION +  
 SIZE OF ANY  
 SECONDARY STRUCTURE

SITE PLAN SHOWING

~~7'6" MIN. CEIL. HT.~~

PROVIDE ADEQUATE CLEARANCE TO  
 WALLS TOP 36"  
 FROM SD 12"

? IS PLASTIC VENT OK  
CEILING HT.

IS A NEW ELRC SERVICE REQ. EXISTING

WHAT TYPE OF SHEATHING  
DRYWALL INTERIOR

TRUSS DIAGRAM

IS THEIR EXISTING OFF STREET PARKING  
 LOT COURAGE NEW 770

EXIST. 2020

2790

= 1235%

~~ESTIMATED = 6 CIRCUM~~

IS THE ELRC SERVICE EXISTING YES





CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR BUILDING PERMIT  
(Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 1415 GREENWOOD Cost of project \$ 11,967.46  
Owner's Name GARY REBEAU Address 1415 GREENWOOD  
Contractor SAME AS ABOVE Telephone No. 599-2231  
Address 1415 GREENWOOD

Lot Information: (Not required for siding job)

Lot No. 29 Subdivision HARMONY ACRES  
Zoning District \_\_\_\_\_ Lot Size 100ft. X 120ft. Area 11,951.72 sq. ft.  
Setbacks: Front 30' Right Side 7' Left Side 30' Rear 58.34

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
New Construction \_\_\_\_\_ Addition  Remodel \_\_\_\_\_

Accessory Building \_\_\_\_\_ Siding ALUMINUM (SARIED ON PAINTED)  
(Specific Type)

Brief Description of Work:----- Building on to existing  
HOUSE, Addition To BE 22' X 35'

Size: Length 35' Width 22' No. of Stories 1  
Area: 1st Floor 770 sq. ft. Basement 682 sq. ft.  
2nd Floor \_\_\_\_\_ sq. ft. Accessory Bldg. \_\_\_\_\_ sq. ft.  
3rd Floor \_\_\_\_\_ sq. ft. Other \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date 5-29-86 Applicant's Signature Gary J. Rebeau

DRAW PLOT PLAN REVERS SIDE

PERMIT NO. \_\_\_\_\_  
PERMIT FEE \$ \_\_\_\_\_





CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Gary Rebeau Address 1415 Glenwood Ave.

Electrical Contractor Brandt Bros Inc Telephone No. 419-267-3640

Address PO Box 158. Ridgerville Corners Ohio

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 1415 Glenwood Ave Cost of Project 1000<sup>00</sup>

Work Information:

Residential 1 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

No. Units

New \_\_\_\_\_ Service Change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring X

Brief Description of Work: Use Present 200 Amp breaker box - remove

120 volt heating Circuits - using created spaces for new circuit new add.

Size of proposed service entrance \_\_\_\_\_ Number of new circuits 6-110V 20A  
2-GFCI-20A

Type of proposed service entrance \_\_\_\_\_ Underground \_\_\_\_\_ Overhead \_\_\_\_\_

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

\*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service: and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

\*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 5-29-86 Applicant's Signature Gary Rebeau

PERMIT NO.

PERMIT FEE \$



CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR PLUMBING PERMIT  
 (Please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only).

Owner's Name GARY L. REBEAU Address 1415 GLENWOOD

Plumbing Contractor SELF Telephone No. 599-2231

Address \_\_\_\_\_

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 1415 GLENWOOD Cost of Project \$1500.00

Work Information:

No. of dwelling units \_\_\_\_\_ New \_\_\_\_\_ Replacement \_\_\_\_\_ Addition X

Brief description of work: CONNECTING UP WATER LINES & SEWER LINES TO EXISTING LINES FOR NEW BATHROOM!

Is water tap required NO Size \_\_\_\_\_ Type of Pipe \_\_\_\_\_

Is sewer tap required NO Size \_\_\_\_\_ Type of Pipe \_\_\_\_\_

Type of Water Distribution pipe COPPER

Type of Drainage, Waste and Vent Pipe PVC

Size of main building drain 4" Size of main vent pipe 4"

Water closets 1 Bathtubs \_\_\_\_\_ Shower 1 1 1/2"  
 No. Trap Size No. Trap Size

Lavatories 1 1 1/2" Kitchen Sink \_\_\_\_\_ Disposal \_\_\_\_\_  
 No. Trap Size No. Trap Size No. Trap Size

Dishwasher \_\_\_\_\_ Clothes Washer \_\_\_\_\_ Other \_\_\_\_\_  
 No. Trap Size No. Trap Size No. Trap Size

All installations are subject to plumbing tests and/or inspections.

Date 5-29-86 Applicant's Signature Gary L. Rebeau

PERMIT NO. \_\_\_\_\_  
 PERMIT FEE \$ \_\_\_\_\_





100 run 7-28-76

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR HEATING PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, repla or alteration of a heating system or device as herein specified, agr to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name Gary Rebeau Address 1415. Elenwood Ave

Contractor's Name Brandt Bros Inc Address Ridgeville Corners Tel 419-267-3640

BUILDING INFORMATION:

Single Family  Double Family  Multiple  New Construction   
Addition  Remodel  Replacement  No. of Stories 1

DESCRIPTION OF WORK

Heating System - Warm Air  Hot Water  Steam  Electric

Unit Heaters  Unit Gas Heaters  Other NAT GAS FURNACE

Type - Gravity  Forced  Radiant

No. of Thermostatical Heating Zone 1

Hot Water - One Pipe  Two Pipe  Series Loop

Electric Heat - No. of Circuits  Other

Total Heat Loss of Area to be Heated App 80,000 BTU.

Rated Capacity of Furnace/Boiler 100,000 in - 91500 BTUS OUTAPP

No. of Furnaces 1 No. of Hot Air Runs 14

No. of Hot Water Radiators 1 Type of Fuel NAT Gas

Heating Units Located: Crawl Space  Floor Level  Suspended

Roof or Exposed to Outside Air  Attic  Other

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF P INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE


ESTIMATED COST OF COMPLETED PROJECT: 3000.00

DATE 5-29-86 APPLICANT'S SIGNATURE Gary Rebeau  
OWNER-CONTRACTOR-AGEN





Figure No. R-303  
MINIMUM FOUNDATION REQUIREMENTS



NOTE:  
Foundations shall extend not less than 12" below the finished undisturbed natural grade or engineered fill and in no case less than the frost line depth.

EXCEPTION:

The finished grade of the underfloor space may be located at the bottom of the footings; however, where there is evidence that the ground water table can rise to within six (6) inches of the finished grade at the building perimeter or where there is evidence that surface water does not readily drain from the building site the Building Official may require that the grade in the under floor space be as high as the outside finished grade, unless an approved drainage system is provided.

NOTE: Footing sizes are based on soil with an allowable soil pressure of two thousand (2000) pounds per square foot. Footings on soil with a lower allowable soil pressure shall be designed in accordance with accepted engineering practice.

Table R-304.5  
REINFORCEMENT REQUIRED FOR FOUNDATION WALLS  
SUBJECTED TO NO MORE PRESSURE THAN WOULD BE  
EXERTED BY BACKFILL HAVING AN EQUIVALENT FLUID  
WEIGHT OF 30 POUNDS PER CUBIC FOOT LOCATED IN  
SEISMIC ZONES NO. 2 AND NO. 3, OR SUBJECTED IN  
TO UNSTABLE SOIL CONDITIONS

Material Type	Height of Unbalanced Fill in Feet	Length of Wall Between Supporting Masonry or Concrete Walk in Feet	Minimum <sup>1</sup> Wall Thickness in inches <sup>2</sup>	Required Reinforcing	
				Horizontal Bar in Upper 12 Inches of Wall	Size and Spacing of Vertical Bars
Hollow Masonry	4 or less	unlimited	8	not required	not required
	more than 4	design required	design required	design required	design required
Concrete or Solid Masonry <sup>3</sup>	4 or less	unlimited	8	not required	not required
	more than 4	less than 8	8	2-No. 3	No. 3 @ 18" O.C.
	8 or less	8 to 10	8	2-No. 4	No. 3 @ 18" O.C.
	8 or less	10 to 12	8	2-No. 5	No. 3 @ 18" O.C.
	more than 8	design required	design required	design required	design required

<sup>1</sup>Thickness of concrete walls may be six (6) inches provided reinforcing is placed not less than one (1) inch nor more than two (2) inches from the face of the wall not against the earth.  
<sup>2</sup>Solid masonry shall include solid brick or concrete units and hollow concrete units with all cells grouted.  
<sup>3</sup>Backfilling shall not be commenced until after the wall is anchored to the floor.  
<sup>4</sup>The actual thickness shall not be more than one-half (1/2) inch less than the required thickness specified in the table.

Section R-305—Foundation Drainage

**R-305.1—Drains Required.** Drains shall be provided around foundations enclosing habitable or usable spaces located below grade and which are subjected to ground water conditions. Drains shall be installed at or below the area to be protected and shall discharge by gravity or mechanical means into an approved drainage system.

**R-305.2—Installation.** The top joints and perforations of drain tiles shall be protected with strips of building paper and the tiles shall be placed on two (2) inches of crushed rock and covered with not less than six (6) inches of the same material.

