



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

Mayor
Steven Lankenau

May 25, 1993

Members of Council
Dennis L. Filgor, President
John E. Church
Michael J. DeWit
Robert G. Heft
James Hershberger
Terri A. Williams

Mr. Bud Shaw
412 Huddle Road
Napoleon, Ohio 43545

Dear Mr. Shaw:

City Manager
Terry Dunn

Please accept this letter as permission to connect your footer tile at the front of your house to the sanitary sewer lateral from your property to the public sewer in Huddle Road, subject to the provisions stated below.

Finance Director
Rupert W. Schweinhagen

This permission is given pursuant to our correspondence and discussions following your meeting with the Board of Public Affairs and as authorized by Section 52.14 of the Code of Ordinances of the City of Napoleon.

Law Director
Michael J. Wesche

Please be advised of the following, either of which make this permission subject to revocation:

Prosecuting Attorney
David M. Grahn

1. The Ohio EPA or other senior governmental agency may require you to disconnect your footer tile.
2. The City may embark on a City wide program to enforce disconnection of clear water connections.

City Engineer
Marc S. Gerken

In either of these two cases you would need to promptly undo the work authorized by this letter and to install a sump pump, all at your expense.

Please contact Mr. Brent Damman at this office to update your prior permit.


In talking to you today you asked for a statement as to our recommendation when we asked you to cap off your footer tile. The request was made to cap off the footer tile so that there be no clear water connection to the City's sanitary sewer system. The recommendation at the time was also made that you install a sump pump at the rear of your home and run the discharge onto the ground.

I will acknowledge that this recommendation may have left you a wet spot on the ground at the point of discharge, but your crawl space would have been properly drained, and you would not have had moisture problems that may have occurred in the absence of the pump.

Trusting this is satisfactory, but if you have any questions please call.

Thank you also for your patience in working through this problem.

Yours sincerely,

A handwritten signature in black ink, appearing to read "Terry Dunn", written over a horizontal line.

Terry Dunn

cc. Mayor and Council
Board of Public Affairs
Mike Wesche, Law Director
Brent Damman, Building and Zoning Administrator
Marc Gerken, City Engineer

File:SHAW.SAM