

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Wayne Nathan

Address Lot B-7, Wayne Trailer Court

Builder Name Sherman Smith

Address Rt. 2, Napoleon Tel. 503-7791

Lot Information:

Street No. Lot B-7, Wayne Trailer Court

Lot --- Subdivision ---

Lot Dimensions --- Lot Area --- Sq. Ft.

Yard Set Back: Front --- Rear ---

Side --- Side ---

Zoning "R" Intended use of Building: Installing on city utilities pole new 200AMP over-head electrical service entrance, for single family unit.

Building Information:

Single Double Multiple New Construction Addition Remodel

Size: Length --- Width --- No. of Stories ---

Floor Area: 1st Floor --- 2nd Floor --- 3rd Floor --- Basement ---

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical: Wiring 200AMP Electric Heating Electrical Appliances

Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: ---

Date 4/22/76 Applicant Signature Wayne Nathan Owner - Builder - Agent

OWNER OF TRAILER COURT INFORMED OF VIOLATIONS BY HOWES. AWP.

CONDUCTORS TO TRAILER STILL NO PROTECTED IN AN APPROVED MATTER, HOWES DISAPPROVED.

Work Started --- Foundations --- Plumbing, Heating ---

Set Back, Side Lines --- Plumbing (Rough In) --- And Air Conditioning ---

Excavation --- Erecting Frame --- Roof ---

Footing --- Electrical Work 4/22/76 DISAPPROVED BY HOWES.

Comments: 1) NO GROUND
2) PROTECT CONDUCTORS SAVING DRAIN DISCONNECT
3) 2' BELOW FINISH GRADE TO CONDUCTORS

Certificate of Occupancy Issued --- Inspector ---

Permit No.	<u>---</u>			
Issued	<u>---</u>			
By	<u>---</u> Building Inspector			
Valuation	<u>\$150.00</u>			
	Fees	Base	Plus	Total
Construction	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
Plumbing	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
Electrical	<u>\$3.00</u>	<u>---</u>	<u>---</u>	<u>\$3.00</u>
Heating	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
Water Tap	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
Sewer Tap	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
Temporary Elec.	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
TOTAL	<u>\$3.00</u>	<u>---</u>	<u>---</u>	<u>\$3.00</u>

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date April 29, 1976

Permit No. 495-76

Type of Inspection Service Entrance

Type of Occupancy Single Family Unit

Project Name Wayne Barber

Address Lot B-7 Maumee Trailer Court

City Napoleon State Ohio

Approved

Violation XX

Electrical Contractor Sherman Smith

Remarks:

Code Reference

Protection must be provided to conform to the requirements of:

Art. 300-5(d) N.E.C.

Violation -

Open conductors not protected on load side of main disconnect switch subject to mechanical damage and contact by personel wrapping with tape is not suitable for the condition.

Contact Building and Zoning Inspection for re-inspection

CORRECTED AND RE-INSPECTED BY HOWES 6/2/76

Compliance Time Immediately

Inspectors Signature Norman Hayes

Copies To: Joe Distel

White - Applicant Yellow - Engineering Pink - Electrical Inspector

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Wagyn Barber Address Lot B-7 Maumet Trailer Court
Contractor's Name Sherman Smith Address R22 Tel. 592-7791

LOT INFORMATION:

Location of Project _____ Zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing _____ Addition _____

Replacement _____ Remodel _____ Service Change _____

Size: Total Square Foot Per Floor _____ No. of Stories _____

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only _____

Total Number of New Circuits _____ Total Number of New Circuits Excluding Appliance Circuits _____

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric _____ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: 150.00

DATE 4-14-76 APPLICANT'S SIGNATURE Sherman Smith
OWNER-CONTRACTOR-AGENT

